

# AUTOMOTIVE CURRENT TRANSDUCER FLUXGATE TECHNOLOGY

CAB-SF 1500-000, CAB-SF 1500-001, CAB-SF 1500-003, CAB-SF 1500-004, CAB-SF 1500-006, CAB 1500-000, CAB 1500-001



## Introduction

The CAB sensor family has been specially designed for the current measurement of the battery packs found in electric and hybrid vehicles. The CAB-SF 1500 sensor is equipped with electronic mechanisms and software that guarantee a level of reliability that is required by the security concepts of battery management systems.

## Features

- Fluxgate transducer technology
- Busbar mounting or panel mounting
- Unipolar +12 V battery power supply
- Output signal: High speed CAN (500 kpbs).

	CAN Resistor Termination	Casing Version	Other Comments
CAB-SF 1500-000	4800 Ω	Bus bar	
CAB-SF 1500-001	4800 Ω	Panel mounting	
CAB-SF 1500-003	120 Ω	Bus bar	
CAB-SF 1500-004	4800 Ω	Bus bar	Inverted $I_p$ sig
CAB-SF 1500-006	120 Ω	Bus bar	
CAB 1500-000	4800 Ω	Bus bar	
CAB 1500-001	4800 Ω	Panel mounting	

## Special features

- Connector type: Tyco AMP 1473672-1
- Configurable CAN speed
- Configurable CAN ID.

## Advantages

- Low offset
- Total error before ageing  
0.5 % error over temperature range: -40 °C to +85 °C
- Full galvanic separation.
- Compatible with 800 V applications following ISO60664-1 standard.

## Automotive applications

The CAB-SF 1500 is designed to run in a vehicle battery pack or in a battery disconnect unit and cannot be used in an environment exposed to water projections and gravel projections. The CAB-SF 1500 is compliant with Functional Safety standard ISO 26262.


The test plan used to validate the product is described at the end of the document.

## Principle of Fluxgate Transducers

A low-frequency fluxgate transducer is made of a wound core which saturates under low induction.


A current chopper switches the winding's current to saturate the magnetic core alternatively at  $\pm B_{max}$  with a fixed frequency. Fluxgate transducers use the change of the saturation's point symmetry to measure the primary current.

Due to the principle of switching the current, all offsets (electric and magnetic) are cancelled.




Dimensions (in mm)


Busbar version




Panel mounting version



Connector pin out



Primary current direction as below:



Weight and Recommended screwing torque instruction

Busbar Version

- Weight: 94 g  $\pm$ 5 %
- Recommended screwing torque instruction:
  - sensor shall be fixed with M6 fastener
  - tightening torque:
    - screw grade 6.8: 6.6 Nm
    - screw grade 8.8: 7.7 Nm

Bracket Version

- Weight: 91 g  $\pm$ 5 %
- Recommended screwing torque instruction:
  - sensor shall be fixed with 2 M5 fastener
  - tightening torque:
    - screw grade 6.8: 3.8 Nm
    - screw grade 8.8: 4.4 Nm

Laser Marking

Designation	Datacode	2D matrix content	Text marking area
CAB-SF 1500-000	P = Production center ID YY = Last two digit of the year DDD = Day number of the year CC = Machine ID HH = Hour MM = Minute SS = Second J = Machine jig ID	PYYDDDCCHMMSSJ90.D9.65.000.0	
CAB-SF 1500-001		PYYDDDCCHMMSSJ90.D9.65.001.0	
CAB-SF 1500-002		PYYDDDCCHMMSSJ90.D9.65.002.0	
CAB-SF 1500-003		PYYDDDCCHMMSSJ90.D9.65.003.0	
CAB-SF 1500-004		PYYDDDCCHMMSSJ90.D9.65.004.0	
CAB-SF 1500-005		PYYDDDCCHMMSSJ90.D9.65.005.0	
CAB-SF 1500-006		PYYDDDCCHMMSSJ90.D9.65.006.0	
CAB 1500-000		PYYDDDCCHMMSSJ90.H5.65.000.0	
CAB 1500-001		PYYDDDCCHMMSSJ90.H5.65.001.0	
CAB 1500-002		PYYDDDCCHMMSSJ90.H5.65.002.0	
CAB 1500-004		PYYDDDCCHMMSSJ90.H5.65.004.0	

**Absolute ratings (not operating)**

Parameter	Symbol	Unit	Specification	Conditions
Over-voltage	$U_C$	V	24	1 min
Reverse polarity	$U_C$	V	-18	1 min
Minimum supply voltage	$U_{C\ min}$	V	6	continuous
Maximum supply voltage	$U_{C\ max}$	V	18	continuous
Ambient storage temperature	$T_{A\ st}$	°C	-40 /+105	
Creepage distance	$d_{Cp}$	mm	12.5	
Clearance	$d_{Cl}$	mm	12.5	
RMS voltage for AC insulation test	$U_d$	kV	2.5	50 Hz, 1 min
Insulation resistance	$R_{INS}$	MΩ	500	500 V - ISO 16750-2
IP Level			IP41	



**Characteristics in nominal range**

Parameter	Symbol	Unit	Specification			Conditions
			Min	Typical	Max	
<b>Electrical Data</b>						
Supply voltage	$U_C$	V	8	13.5	16	no continuous operation at [8 V - 10 V], [75 °C - 85 °C] if > 1000 A $I_p$ current
Current consumption @ $I_p = 0$ A	$I_C$	mA	50	70	100	8 V < $U_C$ < 16 V, CAN acknowledge
Current consumption @ $\pm I_p = 1500$ A	$I_C$	mA	430	500	1300	8 V < $U_C$ < 16 V, CAN acknowledge
Ambient operating temperature	$T_A$	°C	-40		+85	
<b>Performance Data</b>						
Primary nominal DC or RMS current	$I_{PN}$	A	-1500		1500	
CAN signal 'CSM_BAT_CURRENT' clamping value		A	-1550		1550	For $I_p$ between $\pm 1550$ A and over current value
Primary withstand peak current (maximum)	$\hat{I}_{P\ max}$	A	-1700		1700	
Overload recovery time	$t_s$	ms		10		When $I_p$ goes back under 1550 A
Frequency bandwidth	$BW$	Hz		20		With Periodic CAN message @ 10 ms
Start-up time	$t_{start}$	ms		170		
<b>Analog measurement Channel</b>						
Linearity error	$\epsilon_L$	%		±0.1		At room temperature
Total error: [-1500 A, +1500 A]	$\epsilon_{tot}$	%		±0.5		Over full temperature range Performances are considered with average value over 20 CAN frames (200 ms)
Output noise		mA		±50		With Periodic CAN message @ 10 ms. Peak to peak value. No averaging
<b>Digital measurement channel</b>						
Total error	$\epsilon_{tot}$	%		±7		With a minimum of ±2 A Typical value after ageing Performances are considered with average value over 20 CAN frames (200 ms)

### Typical Error Graph

Analog Channel - Typical error from  $-40\text{ }^{\circ}\text{C}$  to  $85\text{ }^{\circ}\text{C}$ :

Performances are considered with average value over 20 CAN frames (200 ms)



$I_p$	Total error ( $8\text{ V} \leq U_C \leq 16\text{ V}; -40\text{ }^{\circ}\text{C} < T_A < 85\text{ }^{\circ}\text{C}$ )	
	Max error @ 3 sigma	
(A)	(A)	(%)
-1500	$\pm 7.5$	$\pm 0.5$
0	$\pm 0.05$	-
1500	$\pm 7.5$	$\pm 0.5$

## External Magnetic Field Influences

The CAB-SF 1500 delivers an accurate current level measurement. However, to ensure its proper functioning and to ensure the current level accuracy, it is necessary to comply with rules for setting up in the BMS environment. Thus, some conditions must be respected during the design of the environment of the sensor:

- Primary busbar centering
- Busbar shape
- Contactors position

LEM's recommendations can be found in the application notes available on request. Please contact LEM support team to ensure that your busbars design fits with LEM's design guideline.

## Current Ripple Influences

Current ripples on the high voltage DC lines could be induced during power conversion from devices like DC/DC, inverter, on-board charger, and so on.

Current ripples not only negatively impact on the health of li-ion batteries, but also could cause malfunctions of the CAB sensor. The failure mode can manifest itself as a disturbed current measurement due to aliasing effect, leading to internal error when the threshold is exceeded. The malfunctions can be automatically recovered when the ripple current is absent.

Normally the ripple current should be measured and minimized during vehicle system design and development. For proper function of the CAB sensor, the acceptable maximum value of the ripple current should be checked. Please contact LEM support team on the reference values, LEM's recommendations can be found in the application notes available on request.

## CAN output specification

- CAN protocol 2.0B
- Bit order: big endian (Motorola)
- CAN oscillator tolerance: 0.27 %
- No sleep mode capability
- 120 ohm termination resistor to be added externally (except CAB-SF 1500-003, CAB-SF 1500-006), internal CAN impedance = 4800 ohm
- CAB-SF 1500-003 and CAB-SF 1500-006 integrates 120 ohm termination resistor inside sensor
- User guide for CAN modification can be found in the application notes available on request.

## CAB-SF 1500 CAN message table

- CAB1500\_ $I_p$  message overview.  
Default frame ID: 0x3C2; transmit period: 10 ms.

CAN Frame Content								
	7	6	5	4	3	2	1	0
BYTE 0	Sequence Counter $I_p$				Status Power Supply		Status Internal Error	Safety Goal Violation
	MSB			LSB	MSB	LSB		
BYTE 1	Analog Current							
	MSB							
BYTE 2	Analog Current							
BYTE 3	Analog Current							
								LSB
BYTE 4	Digital Curent							
	MSB							
BYTE 5	Digital Curent							
								LSB
BYTE 6	Reserved							
	MSB							LSB
BYTE 7	CRC_ $I_p$							
	MSB							LSB

• **‘SequenceCounter $I_p$ ’ signal**

- Initialized with 0 and incremented by 1 for every subsequent send request
- When the counter reaches the value 15 (0xF), then restart with 1 for the next send request.

• **‘StatusPowerSupply’ signal**

CAN Frame Content									
	7	6	5	4	3	2	1	0	
BYTE 0	Sequence Counter $I_p$				Status Power Supply		Status Internal Error	Safety Goal Violation	
	MSB			LSB	MSB	LSB			

When Power Supply voltage measurement is not available, then ‘StatusPowerSupply’ = “1 1”

Notes:

- At sensor start-up, if supply voltage < 7.8 V or > 16.2 V, no CAN frame emission
- Status details can be found in the application notes available on request.

• **‘Status Internal Error’ signal**

This flag is set to 1 to inform the BMS about two use cases:

- Internal hardware error (reference voltage, DAC errors)
- Over current detected in the busbar - current above 1600 A. In this use case, the Status Internal Error flag is set to 1 (see details on the next page in ‘AnalogCurrent’ signal section)

• **‘Safety Goal Violation’ signal [SG1: Current Sensing Error]**

within the current range of [ -1500 A; -220 A [ and ] +220 A; +1500 A ], if there more than 20% of difference between analog current level and digital current level --> then Safety Goal Violation = 1

within the current range of [ -220 A; 220 A ], if there is a gap above 44 A between analog current level and digital current level --> then Safety Goal Violation = 1

Safe State: To provide Safety Goal violation flag, keep providing data measurement  
FTTI: 500 ms




• ‘Analog Current’ signal

Analog measurement of the primary current

$-1500 \leq I_p \leq +1500$ . ‘Analog Current’ signal =  $I_p$ . Error = 0.5 %

$-1550 \leq I_p < -1500$ . ‘Analog Current’ signal =  $I_p$ . Error = 1 %

$+1500 < I_p \leq +1550$ . ‘Analog Current’ signal =  $I_p$ . Error = 1 %




Here below the values for Byte 1, 2 and 3:

$I_p$	Hex value	MSB	LSB	
		Byte 1	Byte 2	Byte 3
1550.000	97A6B0	97	A6	B0
1500.000	96E360	96	E3	60
0.001	800001	80	00	01
0.000	800000	80	00	00
-0.001	7FFFFFFF	7F	FF	FF
-1500.000	691CA0	69	1C	A0
-1550.000	685950	68	59	50

• ‘Digital Current’ signal

$i_{P\max} \leq I_p < -1550$ . ‘Digital Current’ signal is clamped at  $-1550$  A. Error = NA  
 $+1550 < I_p \leq i_{P\max}$ . ‘Digital Current’ signal is clamped at  $+1550$  A. Error = NA



Digital measurement of the primary current, Byte 4 and 5:

$I_p$	Hex value	MSB	LSB
		Byte 4	Byte 5
1550	860E	86	0E
1500	85DC	85	DC
1	8001	80	01
0	8000	80	00
-1	7FFF	7F	FF
-1500	7A24	7A	24
-1550	79F2	79	F2

• ‘CRC\_  $I_p$ ’ signal

8-bit SAE J1850 CRC calculation of the first seven bytes.

**CAB 1500 CAN message table**

- CAB1500\_ $I_p$  message overview.

Default frame ID: 0x3C2; transmit period: 10 ms.

CAN Frame Content								
	7	6	5	4	3	2	1	0
BYTE 0	Sequence Counter $I_p$				Status Power Supply		Status Internal Error	Reserved
	MSB			LSB	MSB	LSB		
BYTE 1	Analog Current							
	MSB							
BYTE 2	Analog Current							
BYTE 3	Analog Current							
								LSB
BYTE 4	Reserved							
BYTE 5	Reserved							
BYTE 6	Reserved							
BYTE 7	CRC_ $I_p$							
	MSB							LSB

- ‘SequenceCounter $I_p$ ’ signal

- Initialized with 0 and incremented by 1 for every subsequent send request
- When the counter reaches the value 15 (0xF), then restart with 1 for the next send request

- ‘StatusPowerSupply’ signal

CAN Frame Content								
	7	6	5	4	3	2	1	0
BYTE 0	Sequence Counter $I_p$				Status Power Supply		Status Internal Error	Reserved
	MSB			LSB	MSB	LSB		

When Power Supply voltage measurement is not available, then ‘Status Power Supply’ = “1 1”

Notes:

- At sensor start-up, if supply voltage < 7.8 V or > 16.2 V, no CAN frame emission
- Status details can be found in the application notes available on request.

• ‘Status Internal Error’ signal

Internal hardware error (reference voltage, DAC errors).


• ‘Analog Current’ signal

Analog measurement of the primary current

$-1500 \leq I_p \leq +1500$ . ‘Analog Current’ signal =  $I_p$ . Error = 0.5 %

$-1550 \leq I_p < -1500$ . ‘Analog Current’ signal =  $I_p$ . Error = 1 %

$+1500 < I_p \leq +1550$ . ‘Analog Current’ signal =  $I_p$ . Error = 1 %



Here below the values for Byte 1, 2 and 3:

$I_p$	Hex value	MSB	LSB	
		Byte 1	Byte 2	Byte 3
1550.000	97A6B0	97	A6	B0
1500.000	96E360	96	E3	60
0.001	800001	80	00	01
0.000	800000	80	00	00
-0.001	7FFFFFFF	7F	FF	FF
-1500.000	691CA0	69	1C	A0
-1550.000	685950	68	59	50

• ‘CRC\_  $I_p$ ’ signal

8-bit SAE J1850 CRC calculation of the first seven bytes.

Applicable standards - Functional Safety - CAB-SF 1500

Safety		
Functional Safety (ASIL C compliant)	ISO 26262 (11/2018)	<p>Safety Manual Table of Contents</p> <ul style="list-style-type: none"> <li>1 DOCUMENT               <ul style="list-style-type: none"> <li>1.1 Applicable documents</li> <li>1.2 Reference documents</li> </ul> </li> <li>2 GLOSSARY</li> <li>3 Introduction</li> <li>4 Assumption</li> <li>5 Product overview               <ul style="list-style-type: none"> <li>5.1 Purpose</li> <li>5.2 Type of Current Sensor</li> <li>5.3 Safety Element out of Context (SEooC)</li> <li>5.4 Functional Block Diagram</li> <li>5.5 Mission Profile</li> </ul> </li> <li>6 Safety Measures               <ul style="list-style-type: none"> <li>6.1 Safety Goal allocated to the sensor</li> <li>6.2 Safety Concept</li> <li>6.3 Description of the maintenance activities expected from the customer</li> <li>6.4 Description of the maintenance activities expected from the customer in the case of a failure indicated by the warning and degradation concept</li> </ul> </li> <li>7 Hardware Requirements on System Level               <ul style="list-style-type: none"> <li>7.1 Datasheet Compliance</li> </ul> </li> <li>8 Software Requirements on System Level               <ul style="list-style-type: none"> <li>8.1 DTC Monitoring</li> </ul> </li> <li>9 Failure Rates and FMEDA               <ul style="list-style-type: none"> <li>9.1 FMEDA Reference Document</li> <li>9.2 FMEDA Applicable Standard</li> <li>9.3 Failure Mode Distribution</li> <li>9.4 FMEDA Results</li> </ul> </li> <li>10 Provisions Against Dependent Failures               <ul style="list-style-type: none"> <li>10.1 External Parasitic Magnetic Fields</li> <li>10.2 Environmental constraints</li> </ul> </li> <li>11 Measures to Prevent Systematic Failures               <ul style="list-style-type: none"> <li>11.1 Parasitic Magnetic Fields due to Bus Bar design</li> <li>11.2 Current Ripple Influences</li> <li>11.3 CAB-SF 1500-C Fastening</li> </ul> </li> <li>12 Diagnostic               <ul style="list-style-type: none"> <li>12.1 Diagnostic Trouble Codes Monitoring</li> <li>12.2 Diagnostic Mode / Maintenance Operation</li> </ul> </li> <li>13 Safety-related content of the instructions for operation, service and decommissioning</li> <li>14 Field Monitoring</li> </ul>

\*Safety Manual availability after NDA and assurance of business signed.

**Applicable standards - PV tests performed - CAB-SF 1500**

Test	Standard	Procedure
CHARACTERIZATION AT 25 °C (Initial and final)	LEM CO.60.09.014.0	Sensitivity; Total error; Offset; Linearity error; Current Consumption
CHARACTERIZATION IN TEMPERATURE RANGE (Initial and final)	LEM CO.60.09.014.0	Sensitivity; Total error; Offset; Linearity error; Current Consumption
<b>Environmental test</b>		
Ageing 85 °C /85 % RH	JESD 22-A101 (03/2009)	$T^{\circ}\text{C} = 85^{\circ}\text{C}$ ; $RH = 85\%$ ; Duration = 1000 h Sensor not supply Check After stab. @ 25 °C (End test) Performance after test, from -40 °C to 85 °C: $I_O \leq 50\text{ mA}$ , $\epsilon_{\text{tot}} \leq 1\%$
Low temperature storage	ISO 16750-4 § 5.1.1.2 (04/2010)	$T^{\circ}\text{C} = -40^{\circ}\text{C}$ Duration = 24 h; Power off, no monitoring Check After stab. @ 25 °C (End test)
High temperature storage	ISO 16750-4 § 5.1.2.2 (04/2010)	$T^{\circ}\text{C} = 85^{\circ}\text{C}$ Duration = 96 h; Power off, no monitoring Check After stab. @ 25 °C (End test)
Temperature cycle with specified change rate	ISO 16750-4 § 5.3.1 (04/2010)	$T^{\circ}\text{C} = -40^{\circ}\text{C}$ & $+85^{\circ}\text{C}$ , see Fig. 2 of ISO 16750-4 Duration = 30 cycles; 1 cycle = 8 h Total duration = 10 days $U_C = 13.5\text{ V}$ ( $\equiv$ connected); $I_P = 0\text{ A}$ ; no monitoring Check After stab. @ 25 °C (End test)
Thermal shock	ISO 16750-4 § 5.3.2 (04/2010)	$T^{\circ}\text{C} = "T^{\circ}\text{C Operating min \& max" -40 to +85^{\circ}\text{C}$ Duration = 300 cycles according to the climatic code (defined table 4); Exposure time : 30 min. $U_C = \text{NO power supply}$ ( $\equiv$ unconnected) and No wiring harness Check After stab. @ 25 °C (End test)
Random Vibration	ISO 16750-3 § 4.1.2.4 (12/2012)	Random; -40 °C /+85 °C during 8 hours; 8 h for each axis and each DUT; RMS acceleration 27.1 m/s <sup>2</sup> Torque measurement before and after. Connected but not supply. No monitoring
Mechanical Shocks	ISO 16750-3 § 4.2 (12/2012)	Temperature: Ambient temperature. Default § 4.2.2 Operating mode: 3.2 Pulse shape: half sine, 50 G, 6 ms 10 shocks per direction (total 60) & Meas. torque Bef. and After Offset before and after; Parts not connected Check After stab. @ 25 °C (End test)
Free Fall	ISO 16750-3 § 4.3 (12/2012)	Number of devices: 3 Falls/DUT: 2 Height = 1 m on Concrete floor 3 axes; 2 directions by axis; 1 sample by axis Operating mode: 1.1 Temperature: 25 °C if not specified Check after test at 25 °C and visual inspection
Cross section checking on PCBA	IPC-A-610G: 2017 Class 3	IPC-TM-650 2.1.1F:2015
Cross section checking on solderless connections	GB/T 18290.5-2015	IPC-TM-650 2.1.1F:2015
Whisker checking on PCBA	Refer to JESD201-A (04/2010)	Refer to JESD22-A121A (04/2010) Class 2
Insulation high voltage	ISO 16750-2 § 4.12 (12/2012) IEC 60664-1	3.5 KV AC 50 Hz 60 s 1000 V DC for 60 s Resistance criteria: > 1000 Mohm

**Applicable standards - PV tests performed - CAB-SF 1500**

Test	Standard	Procedure
<b>Electrical test</b>		
Reverse voltage	ISO 16750-2 § 4.7 (12/2012)	Test performed at room temperature By default: case 2; Duration : 60 s; Level defined in table 7 according to the nominal system voltage
Overvoltage (for 12 V nominal voltage)	ISO 16750-2 § 4.3.1 (12/2012)	$T^{\circ}\text{C} = T_{\text{max}} - 20^{\circ}\text{C}$ and room temperature; At $T_{\text{max}}$ , apply 18 V for 60 min to all inputs; At room temperature, apply 24 V for 60 s
Superimposed alternating voltage	ISO 16750-2 § 4.4 (12/2012)	12 V system severity1: 1 V peak to peak according to Fig. 2 triangular, logarithmic 5 times sweep continuously
Slow decrease and increase of supply voltage	ISO 16750-2 § 4.5 (12/2012)	Test performed at room temperature $U_{\text{S min}} = 8.5 \text{ V}$ Decrease from $U_{\text{S min}}$ to 0 V and increase from 0 V to $U_{\text{S min}}$ ; Change rate: 0.5 V/min
Momentary drop in supply voltage	ISO 16750-2 § 4.6.1 (12/2012)	Test performed at room temperature $U_{\text{C min}} = 8.5 \text{ V}$ $U_{\text{C min}}$ to 4.5 V See Fig. 4
Reset behaviour at voltage drop	ISO 16750-2 § 4.6.2 (12/2012)	Test performed at room temperature See Fig. 6
Load dump	ISO 16750-2 § 4.6.4 (12/2012)	Test performed at room temperature Pulse B, Pulse described in tables 6 'System with 12 V nominal voltage Class C $U_{\text{A}} = 14 \text{ V}$ , $U_{\text{S}}^* = 35 \text{ V}$ , $U_{\text{S}} = 80 \text{ V}$ , $R_{\text{i}} = 1 \text{ ohm}$ $T_{\text{d}} = 400 \text{ ms}$ , 5 pulses at 1 min intervals See Fig. 9
Ground reference and supply voltage	ISO 16750-2 § 4.8 (12/2012)	Test performed at room temperature and test method defined at § 4.8.2
Signal line interruption	ISO 16750-2 § 4.9.1 (12/2012)	Operating the sensor and open the circuit line after line. Opening duration for each line: 10 s
Short circuit protection-Signals circuits	ISO 16750-2 § 4.10.2 (12/2012)	Connect all inputs and outputs to $U_{\text{S max}} = 16 \text{ V}$ and to GND for a duration of 60 s
Insulation test	ISO 16750-2 § 4.11 (12/2012)	Remaining time: 0.5 h $U = 500 \text{ V}$ , 50 Hz for 60 s

Test	Standard	Procedure
<b>EMC test</b>		
Immunity to Electrostatic Discharges (Handling of devices)	ISO 10605 (07/2008)	Contact discharges: $\pm 8$ kV; Air discharges: $\pm 15$ kV. $U_c =$ NO power supply ( $\equiv$ unconnected) Criteria B
Immunity to Radiated disturbances (ALSE)	ISO 11452-2 (11/2004)	Test level II and Test level IV <ul style="list-style-type: none"> <li>· CW and AM in the [200 MHz – 800 MHz] frequency band.</li> <li>· CW, AM and PM1 in the [800 MHz – 1 GHz] frequency band.</li> <li>· CW and PM1 in the [1 GHz – 1.2 GHz] frequency band.</li> <li>· CW and PM2 in the [1.2 GHz – 1.4 GHz] frequency band.</li> <li>· CW and PM1 in the [1.4 GHz – 2.7 GHz] frequency band.</li> <li>· CW and PM2 in the [2.7 GHz – 3.2 GHz] frequency band.</li> </ul> Acceptance, Criteria B / Level 1 for level II Acceptance, Criteria B / Level 2 for level IV
Transient Disturbances Conducted along Supply Lines	ISO 7637-2 (03/2008)	test pulse : 1 : $-100$ V $t_1 = 5$ s (0.2 to 5 s) 2a : $50$ V $t_1 = 0.2$ to 5 s 2b : $10$ V $t_d = 2$ s 3a : $U - 150$ V 3b : $U 100$ V
Transient Disturbances Conducted along I/O or Sensor Lines	ISO 7637-3 (07/2007)	12 V nominal supply voltage Fast a : CCC $-150$ V 10 min Fast b : CCC $+100$ V 10 min slow pulse positive: ICC $+20$ V 20 min slow pulse negative: ICC $-20$ V 20 min
Immunity to Conducted disturbances (BCI)	ISO 11452-4 (12/2011)	Table E.1 Test level I, 1 MHz to 3 MHz : $60$ mA * F(MHz) /3   3 to 400 MHz : $60$ mA Test level II, 1 MHz to 3 MHz : $100$ mA * F(MHz) /3   3 to 400 MHz : $100$ mA Test level IV, 1 MHz to 3 MHz : $200$ mA * F(MHz) /3   3 to 400 MHz : $200$ mA Acceptance, Criteria B / Level 2
Conducted emission - Voltage method	CISPR 25 (2016) § 6.3	Table 5, Class 3, BROADCAST and MOBILE SERVICES Freq = 0.15 MHz to 108 MHz
Radiated emission - ALSE	CISPR 25 (2016) § 6.5	Table 7, Class 3, BROADCAST and MOBILE SERVICES
Immunity to magnetic fields	ISO 11452-8 (2015 E)	12 V Nominal supply voltage radiating loop method Test requirement see TableA.1(Internal filed) Test level I FPSC Status I



单击下面可查看定价，库存，交付和生命周期等信息

[>>LEM\(莱姆\)](#)