QUINT4-PS/24DC/24DC/5/PT/CO

DC/DC converter

Data sheet 109371_en_00

© PHOENIX CONTACT 2021-04-27

1 Description

QUINT POWER DC/DC converters with SFB Technology and preventive function monitoring ensure superior system availability.

Powerful

- SFB Technology: 6 times the nominal current for 15 ms
- Power reserves:
 Static boost of up to 125% (P_N) for a sustained period
 Dynamic boost of up to 200% (P_N) for 5 s

Robust

- ATEX/IECEx approval with protective coating

Preventive

 Comprehensive signaling: Analog signal, digital signal, relay contact, LED bar graph

Flexible connection technology

- Tried-and-tested screw connection
- Fast Push-in connection

Technical data (short form)

Input voltage range	24 V DC -25 % +40 %
Mains buffering	typ. 14 ms (24 V DC)
Nominal output voltage (U _N)	24 V DC
Setting range of the output voltage (U_{Set})	24 V DC 28 V DC
Nominal output current (I _N) Static Boost (I _{Stat.Boost}) Dynamic Boost (I _{Dyn.Boost}) Selective Fuse Breaking (I _{SFB})	5 A 6.25 A 10 A (5 s) 30 A (15 ms)
Output power (P _N) Output power (P _{Stat. Boost}) Output power (P _{Dyn. Boost})	120 W 150 W 240 W (5 s)
Efficiency	typ. 92.2 % (24 V DC)
Residual ripple	< 10 mV _{PP}
MTBF (IEC 61709, SN 29500)	> 930000 h (40 °C)
Ambient temperature (operation)	-40 °C 70 °C > 60 °C Derating: 2.5 %/K
Dimensions W/H/D	36 mm / 130 mm / 125 mm
Weight	0.6 kg



All technical specifications are nominal values and refer to a room temperature of 25 °C and 70 % relative humidity at 100 m above sea level.





Downloaded From Oneyac.com



2	Table of contents	
1	Description	1
2	Table of contents	2
3	Ordering data	3
4	Technical data	5
5	Safety and installation notes	15
6	High-voltage test (HIPOT)	17
7	Structure of the power supply	18
8	Mounting/removing the power supply	21
9	Device connection terminal blocks	25
10	Output characteristic curves	26
11	Configuring the power supply	29
12	Boost currents	30
13	SFB Technology	32
14	Signaling	
15	Operating modes	44
16	Derating	46

3 Ordering data

Description	Туре	Order No.	Pcs./Pkt.
Primary-switched DC/DC converter, QUINT POWER, DIN rail mounting, SFB Technology (Selective Fuse Breaking), Push-in connection, input: 24 V DC, output: 24 V DC / 5 A	QUINT4-PS/24DC/24DC/5/ PT/CO	2910132	1
Accessories	Туре	Order No.	Pcs./Pkt.
Universal wall adapter for securely mounting the device in the event of strong vibrations. The device is screwed directly onto the mounting surface. The universal wall adapter is attached on the top/bottom.	UWA 182/52	2938235	1
2-piece universal wall adapter for securely mounting the device in the event of strong vibrations. The profiles that are screwed onto the side of the device are screwed directly onto the mounting surface. The universal wall adapter is attached on the left/right.	UWA 130	2901664	1
Assembly adapter for QUINT-PS power supply on S7- 300 rail	QUINT-PS-ADAPTERS7/1	2938196	1
Near Field Communication (NFC) programming adapter with USB interface for the wireless configuration of NFC- capable products from PHOENIX CONTACT with software. No separate USB driver is required.	TWN4 MIFARE NFC USB ADAPTER	2909681	1
Multi-channel electronic circuit breaker for protecting four loads at 24 V DC in the event of overload and short circuit. With electronic locking of the set nominal currents. For installation on DIN rails.	CBMC E4 24DC/1-4A NO	2906031	1
Multi-channel electronic circuit breaker for protecting four loads at 24 V DC in the event of overload and short circuit. With electronic locking of the set nominal currents. For installation on DIN rails.	CBMC E4 24DC/1-10A NO	2906032	1
Multi-channel electronic circuit breaker with IO-Link interface for protecting four loads at 24 V DC in the event of overload and short circuit. With electronic locking of the set nominal currents. For installation on DIN rails.	CBMC E4 24DC/1-4A+ IOL	2910410	1
Multi-channel electronic circuit breaker with IO-Link interface for protecting four loads at 24 V DC in the event of overload and short circuit. With electronic locking of the set nominal currents. For installation on DIN rails.	CBMC E4 24DC/1-10A IOL	2910411	1

Accessories	Туре	Order No.	Pcs./Pkt.
Multi-channel, electronic circuit breaker with active current limitation for protecting four loads at 24 V DC in the event of overload and short circuit. With nominal current assistant and electronic locking of the set nominal currents. For installation on DIN rails.	CBM E4 24DC/0.5-10A NO-R	2905743	1
Multi-channel, electronic circuit breaker with active current limitation for protecting eight loads at 24 V DC in the event of overload and short circuit. With nominal current assistant and electronic locking of the set nominal currents. For installation on DIN rails.	CBM E8 24DC/0.5-10A NO-R	2905744	1
The range of accessories is being continuous the download area for the product.	ly extended. The current range of	of accessories c	an be found in

4 Technical data

Input data

Unless otherwise stated, all data applies for 25°C ambient temperature, 24 V DC input voltage, and nominal output current (I_N) .

Input voltage range	24 V DC -25 % +40 %
Electric strength, max.	35 V DC (60 s)
Current draw typ.	6.9 A (24 V DC)
Mains buffering	typ. 14 ms (24 V DC)
Switch-on time	<1s
Typical response time from SLEEP MODE	300 ms
Inrush current limitation	1 A
Inrush current integral (I ² t)	< 0.05 A ² s
Input fuse slow-blow, internal	15 A



During the first few microseconds, the current flow into the filter capacitors is excluded.



The SCCR value (short-circuit current rating) of the power supply unit corresponds to the SCCR value of the backup fuse (see input protection table).




The external backup fuse must be approved for the (DC) supply voltage used and the voltage level.

Input protection, DC (to be connected externally upstream)

Input current I _{In} Input protection	Circuit breaker			Neozed fuse or equivalent	Power switch		
Characteristics	A	в	С	D	к	gG	≤ 13 x l _{ln} (maximum magnetic tripping)
16 A	-	\checkmark	\checkmark	\checkmark	\checkmark	✓	-


¹

Electric strength of the insulation



	Α	В	С	D
Type test (IEC/EN 61010-1)	2 kV DC	4 kV DC	0.5 kV DC	0.5 kV DC
Production test	2 kV DC	2 kV DC	0.5 kV DC	0.5 kV DC

Input current vs. output current



Input connection data	
Connection method	Push-in connection
Conductor cross section, rigid	0.2 mm ² 6 mm ²
Conductor cross section, flexible	0.2 mm ² 6 mm ²
Conductor cross section flexible, with ferrule with plastic sleeve	0.2 mm ² 4 mm ²
Conductor cross section flexible, with ferrule without plastic sleeve	0.2 mm ² 4 mm ²
Conductor cross section AWG	24 10
Stripping length	10 mm

Output data	
Nominal output voltage (U _N)	24 V DC
Setting range of the output voltage (U_{Set}) (> 24 V DC, constant capacity)	24 V DC 28 V DC
Nominal output current (I _N)	5 A
Static Boost (I _{Stat.Boost})	6.25 A
Dynamic Boost (I _{Dyn.Boost})	10 A (5 s)
Selective Fuse Breaking (I _{SFB})	30 A (15 ms)
Magnetic circuit breaker tripping	A1 A4 / B2 / C1 C2 / Z1 Z4
Control deviation change in load, static 10 $\% \dots$ 90 $\%$	< 1 %
Control deviation Dynamic load change 10 $\%$ 90 $\%,$ 10 Hz	< 3 %
Control deviation change in input voltage ± 10 %	< 0.1 %
Short-circuit-proof	yes
No-load proof	yes
Residual ripple	< 10 mV _{PP}
Connection in parallel	Yes, for redundancy and increased capacity
Connection in series	yes
Feedback voltage resistance	≤ 35 V DC
Protection against overvoltage at the output (OVP)	≤ 30 V DC
Rise time typical	< 1 s (U _{OUT} (10 % 90 %))
Output connection data	
Connection method	Push-in connection
Conductor cross section, rigid	0.2 mm ² 6 mm ²
Conductor cross section, flexible	0.2 mm ² 6 mm ²
Conductor cross section flexible, with ferrule with plastic sleeve	0.2 mm² 4 mm²
Conductor cross section flexible, with ferrule without plastic sleeve	0.2 mm ² 4 mm ²
Conductor cross section AWG	24 10
Stripping length	10 mm
LED signaling	
P _{Out} > 100 %	LED lights up yellow, output power > 120 W
P _{Out} > 75 %	LED lights up green, output power > 90 W
P _{Out} > 50 %	LED lights up green, output power > 60 W
U _{Out} > 0.9 x U _{Set}	LED lights up green
U _{Out} < 0.9 x U _{Set}	LED flashes green
UIn > 0.8 x U _{InNom}	LED off
UIn < 0.8 x U _{InNom}	LED lights up yellow

Signal contacts	
Signal output Out 1 (configurable)	
Connection labeling	3.5 +
Digital	0 / 24 V DC , 20 mA
Default	U _{IN} input voltage OK
Signal option	Output voltage Output current Output power Operating hours Early warning of high temperatures OVP voltage limitation active
Signal output Out 2 (configurable)	
Connection labeling	3.6 +
Digital	0 / 24 V DC , 20 mA
Default	Output power
Signal option	Output voltage Output current Operating hours Early warning of high temperatures OVP voltage limitation active
Analog	4 mA 20 mA ±5 % (Load ≤400 Ω)
Signal option	Output voltage Output current Output power
Signal output Relay 13/14 (configurable)	
Connection labeling	3.1, 3.2
Switch contact (floating)	floating
Maximum contact load	24 V DC 1 A , 30 V AC 0.5 A
Default	Output voltage
Signal option	Output current Output power Operating hours Early warning of high temperatures OVP voltage limitation active U _{IN} input voltage OK
Remote signal input (configurable)	
Connection labeling	3.3 +
Function	Output power ON/OFF (remote)
Default	Output power ON (>40 k $\Omega/24$ V DC/open bridge between REM and SGnd)
Signal ground SGnd	
Connection labeling	3.4 +
Function	Signal ground
	to OUT1, OUT2, REM

109371_en_00

PHOENIX CONTACT 8/49

Signal connection data			
Connection method	Push-in connection		
Conductor cross section, rigid	0.2 mm² 1 mm²		
Conductor cross section, flexible	0.2 mm² 1.5 mm²		
Conductor cross section flexible, with ferrule with plastic sleeve	0.2 mm ² 1.5 mm ²		
Conductor cross section flexible, with ferrule without plastic sleeve	0.2 mm ² 1.5 mm ²		
Conductor cross section AWG	24 16		
Stripping length	8 mm		
Reliability	24 \	/ DC	
MTBF (IEC 61709, SN 29500)	> 930000	0 h (25 °C)) h (40 °C)) h (60 °C)	
Life expectancy (electrolytic capacitors) Output current (I _{Out})	24 \	/ DC	
2.5 A	> 422000	h (40 °C)	
5 A	> 260000 h (40 °C)		
5 A	> 520000 h (30 °C)		
The expected service life is based on the cap specified data will be ensured until the end of operation may be reduced. The specified ser	the stated service life. For runtin	nes beyond this time, error-free	
Switching frequency	Min.	Max.	
Auxiliary converter stage	190 kHz	220 kHz	
Main converter stage	50 kHz 420 kHz		
General data			
Degree of protection	IP20		
Protection class	Special with SELV input and output		
Inflammability class in acc. with UL 94 (housing / terminal blocks)	V0		
Side element version	Aluminum		
Hood version	Stainless steel X6Cr17		
Dimensions W / H / D (state of delivery)	36 mm / 130 mm / 125 mm		
Dimensions W / H / D (90° turned)	122 mm / 130 mm / 39 mm		
Weight	0.6 kg		
Power dissipation	24	/ DC	
Maximum power dissipation in no-load condition	<2	2 W	
Power dissipation SLEEP MODE	<	I W	
Power loss nominal load max.	< 1	0 W	

Efficiency	24 V DC
$ \begin{array}{c} $	typ. 92.2 %
Ambient conditions	
Ambient temperature (operation)	-40 °C 70 °C (> 60 °C Derating: 2.5 %/K)
The ambient temperature (operation) refers	to IEC 61010 surrounding air temperature.
Ambient temperature (storage/transport)	-40 °C 85 °C
Max. permissible relative humidity (operation)	≤ 100 % (at 25 °C, non-condensing)
Installation height	≤ 5000 m (> 2000 m, observe derating)
Vibration (operation)	5 Hz 100 Hz resonance search 2.3g, 90 min., resonance frequency 2.3g, 90 min. (according to DNV GL Class C)
Shock	18 ms, 30g, in each space direction (according to IEC 60068- 2-27)
Degree of pollution	2
Climatic class	3K3 (EN 60721)
Overvoltage category EN 61010-1 EN 62477-1	
Standards	
Electrical safety (of control and regulation devices)	IEC 61010-1
Safety extra-low voltage	EN 61010-1 (SELV) IEC 61010-2-201 (PELV)
Mains variation/undervoltage	EN 61000-4-29
EMC requirements, power plant	IEC 61850-3 EN 61000-6-5
Explosive atmospheres	IEC 60079-0 IEC 60079-7 IEC 60079-11 IEC 60079-15

Approvals	
ATEX	SIQ 21 ATEX 024 X li 3 G Ex ec ic nC IIC T4
IECEx	IECEx SIQ 19.0003X Ex ec ic nC IIC T4 Gc
UL	UL Listed UL 61010-1 UL Listed UL 61010-2-201 UL ANSI/ISA-12.12.01 Class I, Division 2, Groups A, B, C, D T4 (Hazardous Location)
CSA	CAN/CSA-C22.2 No. 61010-1-12 CAN/CSA-IEC 61010-2-201:14
SIQ	Type tested (type approved) CB scheme (IEC 61010-1, IEC 61010-2-201)
Shipbuilding	DNV GL ABS

requirementspractice (covered)Conducted noise emission EN 55016EN 61000-6-4 (Class A)EN 61000-6-3 (Class BNoise emission EN 55016EN 61000-6-4 (Class A)EN 61000-6-3 (Class BNoise emission for marine approvalMinimum normative requirements of DNV GLHigher requirements practice of DNV GL (creed)DNV GL conducted noise emissionClass A Area power distributionClass B Bridge and deck areaDNV GL noise radiationClass A Area power distributionClass B Bridge and deck areaImmunity according to EN 61000-6-1 (residential), EN 61000-6-2 (industrial), and EN 61000-6-5 (power statied equipment zone), IEC/EN 61850-3 (energy supply)Minimum normative requirements of EN 61000-6-5 (power statied equipment zone), IEC/EN 61850-3 (energy supply)Higher requirements practice (covered) 6-2 (CE) (immunity for industrial environments)Higher requirements practice (covered) 6-2 (CE)Electrostatic discharge EN 61000-4-24 kV (Test Level 2)8 kV (Test Level 4)Housing contact discharge to using air discharge8 kV (Test Level 3)15 kV (Test Level 4)Electromagnetic HF field EN 61000-4-3Frequency range 8 0 MHz 1 GHz80 MHz 1 GHz 80 MHz 1 GHz80 MHz 1 GHz 20 V/m (Test Level 3)Frequency range to third strength10 V/m (Test Level 3)20 V/m (Test Level 3)20 V/m (Test Level 3)	Electromagnetic compatibility Conformance with EMC Directive 2014/30/EU				
requirementspractice (covered)Conducted noise emission EN 55016EN 61000-6-4 (Class A)EN 61000-6-3 (Class ENoise emission for marine approvalMinimum normative requirements of DNV GLHigher requirements practice of DNV GL cenducted noise emissionClass A Area power distributionClass B 	Noise emission according to EN 61000-6-3 (residentia	al and commercial) and EN 61	000-6-4 (industrial)		
Noise emission EN 55016 EN 61000-6-4 (Class A) EN 61000-6-3 (Class B Noise emission for marine approval Minimum normative requirements of DNV GL Higher requirements of DNV GL DNV GL conducted noise emission Class A Class B DNV GL noise radiation Class A Class B DNV GL noise radiation Class A Class B Immunity according to EN 61000-6-1 (residential), EN 61000-6-2 (industrial), and EN 61000-6-5 (power stati equipment zone), IEC/EN 61850-3 (energy supply) Minimum normative requirements of EN 61000-6-2 (covered) CE basic standard Minimum inormative requirements of EN 61000-6-2 (CE) (immunity for industrial) environments) Higher requirements practice (covered) Electrostatic discharge EN 61000-4-2 Minimum normative requirements of EN 61000-6-3 (Ce) Higher requirements of EN 61000-6-2 (CE) Electromagnetic HF field EN 61000-4-2 Minimum normative Comments Frequency range 8 kV (Test Level 2) 8 kV (Test Level 4) Electromagnetic HF field EN 61000-4-3 Frequency range 80 MHz 1 GHz 80 MHz 1 GHz 80 MHz 1 GHz Comments Comments 3 V/m (Test Level 3) 20 V/m (Test Level 3) 20 V/m (Test Level 3) Frequency range 80 MHz 1 GHz 8 M/m criterion A Criterion A 2 kV (Test	CE basic standard		Higher requirements in practice (covered)		
Noise emission for marine approval Minimum normative requirements of DNV GL. Higher requirements practice of DNV GL (c ered) DNV GL conducted noise emission Class A Area power distribution Class S Bridge and deck area DNV GL noise radiation Class A Area power distribution Class B Bridge and deck area Immunity according to EN 61000-6-1 (residential), EN 61000-6-2 (industrial), and EN 61000-6-5 (power stati equipment zone), IEC/EN 61850-3 (energy supply) Minimum normative requirements of EN 61000- 6-2 (cE) (immunity for industrial environments) Higher requirements practice (covered) Electrostatic discharge EN 61000-4-2 Musing contact discharge Housing air discharge 4 kV (Test Level 2) 8 kV (Test Level 4) 8 kV (Test Level 4) 15 kV (Test Level 4) Electromagnetic HF field EN 61000-4-3 Frequency range Test field strength 80 MHz 1 GHz 10 V/m (Test Level 3) 80 MHz 1 GHz 20 V/m (Test Level 3) Electromagnetic HF field EN 61000-4-3 Frequency range Test field strength 30 V/m (Test Level 3) 20 V/m (Test Level 3) Comments Criterion A Criterion A Criterion A Criterion A Fast transients (burst) EN 61000-4-4 Input 2 kV (Test Level 3 - asymmetrical) 2 kV (Test Level 3 - asymmetrical) 2 kV (Test Level 3 - asymmetrical) Comments Comments Criterion A Criterion A 2 kV	Conducted noise emission EN 55016	EN 61000-6-4 (Class A)	EN 61000-6-3 (Class B)		
requirements of DNV GLpractice of DNV GL (circled)DNV GL conducted noise emissionClass A Area power distributionClass B Bridge and deck areaDNV GL noise radiationClass A Area power distributionClass B Bridge and deck areaImmunity according to EN 61000-6-1 (residential), EN 61000-6-2 (industrial), and EN 61000-6-5 (power stati equipment zone), IEC/EN 61850-3 (energy supply)Minimum normative requirements of EN 61000- 6-2 (CE) (immunity for industrial environments)Higher requirements practice (covered) 6-2 (CE) (immunity for industrial environments)Electrostatic discharge EN 61000-4-24 kV (Test Level 2)8 kV (Test Level 4)Housing contact discharge Comments4 kV (Test Level 3)15 kV (Test Level 4)CommentsCriterion BCriterion AElectrostatic HF field EN 61000-4-3S0 MHz 1 GHz80 MHz 1 GHzElectromagnetic HF field EN 61000-4-310 V/m (Test Level 3)20 V/m (Test Level 3)CommentsCriterion BCriterion AFrequency range Comments1.4 GHz 2 GHz1 GHz 6 GHzFrequency range Comments1.4 GHz 2 CHz1 GHz 6 GHzTest field strength Comments0 V/m (Test Level 3)2 kV (Test Level 3)CommentsCriterion ACriterion AFast transients (burst) EN 61000-4-42 kV (Test Level 3 - asymmetrical)2 kV (Test Level 3 - asymmetrical)Courded2 kV (Test Level 3 - asymmetrical)2 kV (Test Level 3 - asymmetrical)Courded2 kV (Test Level 3 - asymmetrical)2 kV (Test Level 3 - <br< td=""><td>Noise emission EN 55016</td><td>EN 61000-6-4 (Class A)</td><td>EN 61000-6-3 (Class B)</td></br<>	Noise emission EN 55016	EN 61000-6-4 (Class A)	EN 61000-6-3 (Class B)		
Area power distributionBridge and deck areaDNV GL noise radiationClass A Area power distributionClass B Bridge and deck areaImmunity according to EN 61000-6-1 (residential), EN 61000-6-2 (industrial), and EN 61000-6-5 (power stati equipment zone), IEC/EN 61850-3 (energy supply)Higher requirementsCE basic standardMinimum normative requirements of EN 61000- 6-2 (CE) (Immunity for industrial 	Noise emission for marine approval		Higher requirements in practice of DNV GL (cov ered)		
Area power distributionBridge and deck areaImmunity according to EN 61000-6-1 (residential), EN1000-6-2 (industrial), and EN61000-6-5 (power statility)CE basic standardMinimum normative requirements of EN 61000- 6-2 (CE) (immunity for industrial environments)Higher requirements practice (covered) 6-2 (CE)Electrostatic discharge EN 61000-4-24 kV (Test Level 2)8 kV (Test Level 4)Housing contact discharge 	DNV GL conducted noise emission		Class B Bridge and deck area		
equipment zone), IEC/EN 61850-3 (energy supply)Minimum normative requirements of EN 61000- 6-2 (CE) (immunity for industrial 	DNV GL noise radiation		-		
requirements of EN 61000- 6-2 (CE) (immunity for industrial environments)practice (covered)Electrostatic discharge EN 61000-4-2Housing contact discharge Housing air discharge4 kV (Test Level 2)8 kV (Test Level 4)8 kV (Test Level 4)CommentsCriterion BCommentsCriterion BElectromagnetic HF field EN 61000-4-3Electromagnetic HF field EN 61000-4-380 MHz 1 GHzFrequency range Frequency range80 MHz 1 GHz10 V/m (Test Level 3)20 V/m (Test Level 3)20 V/m (Test Level 3)20 V/m (Test Level 3)CommentsCriterion AElectromagnetic HF field Strength Test field strength10 V/m (Test Level 3)20 V/m (Test Level 3)20 V/m (Test Level 3)CommentsCriterion AFrequency range CommentsCriterion AFast transients (burst) EN 61000-4-42 kV (Test Level 3)Comments2 kV (Test Level 3)2 kV (Test L		61000-6-2 (industrial), and E	N 61000-6-5 (power statior		
Housing contact discharge Housing air discharge4 kV (Test Level 2)8 kV (Test Level 4)Housing air discharge Comments8 kV (Test Level 3)15 kV (Test Level 4)CommentsCriterion BCriterion AElectromagnetic HF field EN 61000-4-380 MHz 1 GHz80 MHz 1 GHzFrequency range Test field strength10 V/m (Test Level 3)20 V/m (Test Level 3)Image: Comments10 V/m (Test Level 3)20 V/m (Test Level 3)Frequency range Test field strength1.4 GHz 2 GHz1 GHz 6 GHzTest field strength Comments3 V/m (Test Level 2)10 V/m (Test Level 3)CommentsCriterion ACriterion AFast transients (burst) EN 61000-4-42 kV (Test Level 3- asymmetrical)2 kV (Test Level 3- asymmetrical)Output Signal2 kV (Test Level 3- asymmetrical)2 kV (Test Level 3- asymmetrical)Signal1 kV (Test Level 3- asymmetrical)2 kV (Test Level 3- asymmetrical)	CE basic standard	requirements of EN 61000- 6-2 (CE) (immunity for industrial	Higher requirements in practice (covered)		
Housing air discharge Comments8 kV (Test Level 3)15 kV (Test Level 4)CommentsCriterion BCriterion AElectromagnetic HF field EN 61000-4-380 MHz 1 GHz80 MHz 1 GHzFrequency range Test field strength10 V/m (Test Level 3)20 V/m (Test Level 3)Imput10 V/m (Test Level 2)10 V/m (Test Level 3)CommentsCriterion A10 V/m (Test Level 2)Comments10 V/m (Test Level 2)10 V/m (Test Level 3)CommentsCriterion ACriterion AFast transients (burst) EN 61000-4-42 kV (Test Level 3 - asymmetrical)2 kV (Test Level 3 - asymmetrical)Output2 kV (Test Level 3 - asymmetrical)2 kV (Test Level 3 - asymmetrical)Signal1 kV (Test Level 3 - asymmetrical)2 kV (Test Level 4 - asymmetrical)	Electrostatic discharge EN 61000-4-2				
CommentsCriterion BCriterion AElectromagnetic HF field EN 61000-4-3Frequency range80 MHz 1 GHz80 MHz 1 GHzTest field strength10 V/m (Test Level 3)20 V/m (Test Level 3)Test field strength10 V/m (Test Level 3)20 V/m (Test Level 3)Frequency range1.4 GHz 2 GHz1 GHz 6 GHzTest field strength3 V/m (Test Level 2)10 V/m (Test Level 3)CommentsCriterion ACriterion AFast transients (burst) EN 61000-4-42 kV (Test Level 3 - asymmetrical)2 kV (Test Level 3 - asymmetrical)Output2 kV (Test Level 3 - asymmetrical)2 kV (Test Level 3 - asymmetrical)Signal1 kV (Test Level 3 - asymmetrical)2 kV (Test Level 3 - asymmetrical)	Housing contact discharge	4 kV (Test Level 2)	8 kV (Test Level 4)		
Electromagnetic HF field EN 61000-4-3Frequency range Test field strength80 MHz 1 GHz80 MHz 1 GHzTest field strength10 V/m (Test Level 3)20 V/m (Test Level 3)Frequency range Test field strength1.4 GHz 2 GHz1 GHz 6 GHzTest field strength3 V/m (Test Level 2)10 V/m (Test Level 3)CommentsCriterion ACriterion AFast transients (burst) EN 61000-4-42 kV (Test Level 3 - asymmetrical)2 kV (Test Level 3 - asymmetrical)Output2 kV (Test Level 3 - asymmetrical)2 kV (Test Level 3 - asymmetrical)Signal1 kV (Test Level 3 - asymmetrical)2 kV (Test Level 3 - asymmetrical)	Housing air discharge	8 kV (Test Level 3)	15 kV (Test Level 4)		
Frequency range80 MHz 1 GHz80 MHz 1 GHzTest field strength10 V/m (Test Level 3)20 V/m (Test Level 3)Frequency range1.4 GHz 2 GHz1 GHz 6 GHzTest field strength3 V/m (Test Level 2)10 V/m (Test Level 3)CommentsCriterion ACriterion AFast transients (burst) EN 61000-4-410 put2 kV (Test Level 3 - asymmetrical)Output2 kV (Test Level 3 - asymmetrical)2 kV (Test Level 3 - asymmetrical)Signal1 kV (Test Level 3 - asymmetrical)2 kV (Test Level 3 - asymmetrical)	Comments	Criterion B	Criterion A		
Test field strength10 V/m (Test Level 3)20 V/m (Test Level 3)Frequency range1.4 GHz 2 GHz1 GHz 6 GHzTest field strength3 V/m (Test Level 2)10 V/m (Test Level 3)CommentsCriterion ACriterion AFast transients (burst) EN 61000-4-410 V/m (Test Level 3 - asymmetrical)2 kV (Test Level 3 - asymmetrical)Output2 kV (Test Level 3 - asymmetrical)2 kV (Test Level 3 - asymmetrical)Signal1 kV (Test Level 3 - asymmetrical)2 kV (Test Level 4 - asymmetrical)	Electromagnetic HF field EN 61000-4-3				
Frequency range1.4 GHz 2 GHz1 GHz 6 GHzTest field strength3 V/m (Test Level 2)10 V/m (Test Level 3)CommentsCriterion ACriterion AFast transients (burst) EN 61000-4-4Input2 kV (Test Level 3 - asymmetrical)Output2 kV (Test Level 3 - asymmetrical)2 kV (Test Level 3 - asymmetrical)Signal1 kV (Test Level 3 - asymmetrical)2 kV (Test Level 3 - asymmetrical)	Frequency range	80 MHz 1 GHz	80 MHz 1 GHz		
Test field strength3 V/m (Test Level 2)10 V/m (Test Level 3)CommentsCriterion ACriterion AFast transients (burst) EN 61000-4-410 V/m (Test Level 3)Input2 kV (Test Level 3 - asymmetrical)2 kV (Test Level 3 - asymmetrical)Output2 kV (Test Level 3 - asymmetrical)2 kV (Test Level 3 - asymmetrical)Signal1 kV (Test Level 3 - asymmetrical)2 kV (Test Level 4 - asymmetrical)	Test field strength	10 V/m (Test Level 3)	20 V/m (Test Level 3)		
CommentsCriterion ACriterion AFast transients (burst) EN 61000-4-4Input2 kV (Test Level 3 - asymmetrical)2 kV (Test Level 3 - asymmetrical)Output2 kV (Test Level 3 - asymmetrical)2 kV (Test Level 3 - asymmetrical)2 kV (Test Level 3 - asymmetrical)Signal1 kV (Test Level 3 - asymmetrical)2 kV (Test Level 4 - asymmetrical)	Frequency range	1.4 GHz 2 GHz	1 GHz 6 GHz		
Fast transients (burst) EN 61000-4-4 Input 2 kV (Test Level 3 - asymmetrical) 2 kV (Test Level 3 - asymmetrical) Output 2 kV (Test Level 3 - asymmetrical) 2 kV (Test Level 3 - asymmetrical) Signal 1 kV (Test Level 3 - asymmetrical) 2 kV (Test Level 4 - asymmetrical)	Test field strength	3 V/m (Test Level 2)	10 V/m (Test Level 3)		
Input2 kV (Test Level 3 - asymmetrical)2 kV (Test Level 3 - asymmetrical)Output2 kV (Test Level 3 - asymmetrical)2 kV (Test Level 3 - asymmetrical)Signal1 kV (Test Level 3 - asymmetrical)2 kV (Test Level 4 - asymmetrical)	Comments	Criterion A	Criterion A		
asymmetrical)asymmetrical)Output2 kV (Test Level 3 - asymmetrical)2 kV (Test Level 3 - asymmetrical)Signal1 kV (Test Level 3 - asymmetrical)2 kV (Test Level 4 - asymmetrical)	Fast transients (burst) EN 61000-4-4				
asymmetrical)asymmetrical)Signal1 kV (Test Level 3 - asymmetrical)2 kV (Test Level 4 - asymmetrical)	Input				
asymmetrical) asymmetrical)	Output				
Comments Criterion B Criterion A	Signal	,	•		
	Comments	Criterion B	Criterion A		

CE basic standard Minimum normative Higher requirements in								
	requirements of EN 61000-	practice (covered)						
	6-2 (CE) (immunity for industrial							
	environments)							
Surge voltage load (surge) EN 61000-4-5								
Input	0.5 kV (Test Level 2 -	1 kV (Test Level 3 -						
	symmetrical) 1 kV (Test Level 2 -	symmetrical) 2 kV (Test Level 3 -						
	asymmetrical)	asymmetrical)						
Output	0.5 kV (Test Level 2 -	1 kV (Test Level 3 -						
	symmetrical)	symmetrical)						
	1 kV (Test Level 2 - asymmetrical)	2 kV (Test Level 3 - asymmetrical)						
Signal	1 kV (Test Level 2 -	2 kV (Test Level 3 -						
	asymmetrical)	asymmetrical)						
Comments	Criterion B	Criterion A						
Conducted interference EN 61000-4-6								
Input/Output/Signal	asymmetrical	asymmetrical						
Frequency range	0.15 MHz 80 MHz	0.15 MHz 80 MHz						
Voltage	10 V (Test Level 3)	10 V (Test Level 3)						
Comments	Criterion A	Criterion A						
ower frequency magnetic field EN 61000-4-8								
	50 Hz , 60 Hz (30 A/m)	16.7 Hz , 50 Hz , 60 Hz (100 A/m 60 s)						
	not required	50~Hz , $60~Hz$ ($1~kA/m$, $3~s$						
	not required	0 Hz (300 A/m , DC, 60 s)						
Comments	Criterion A	Criterion A						
Additional basic standard EN 61000-6-5 (immunity in	power station), IEC/EN 61850	-3 (energy supply)						
Basic standard	Minimum normative	Higher requirements in						
	requirements of EN 61000- 6-5	practice (covered)						
Pulse-shape magnetic field EN 61000-4-9								
	not required	1000 A/m						
Comments	none	Criterion A						
Damped oscillating magnetic field EN 61000-4-10								
	not required	100 kHz 100 A/m						
	not required	1 MHz 100 A/m						
Comments	none	Criterion A						

Additional basic standard EN 61000-6-5 (immunity in power station), IEC/EN 61850-3 (energy supply)						
Basic standard		Minimum normative requirements of EN 61000- 6-5	Higher requirements in practice (covered)			
Asymmetrical conducted disturbance	variables EN 61000-	-4-16				
lnរ	out, Output, Signals	15 Hz 150 Hz , 10 V on 1 V 150 Hz 1.5 kHz , 1 V 1.5 kHz 15 kHz , 1 V on 10 V 15 kHz 150 kHz , 10 V (Test Level 3)	15 Hz 150 Hz , 10 V on 1 V 150 Hz 1.5 kHz , 1 V 1.5 kHz 15 kHz , 1 V on 10 V 15 kHz 150 kHz , 10 V (Test Level 3)			
		50 Hz , 60 Hz , 10 V (Permanent) 50 Hz , 60 Hz , 100 V (1 s) (Test Level 3)	16.7 Hz, 50 Hz, 60 Hz, 150 Hz, 180 Hz , 10 V (Permanent) 0 Hz , 16.7 Hz , 50 Hz , 60 Hz , 100 V (1 s) (Test Level 3)			
	Comments	Criterion A	Criterion A			
Alternating component of DC voltage	EN 61000-4-17					
Alternating component		10 % (U _N) , 50 Hz	15 % (U _N) , 50 Hz , 100 Hz , 150 Hz 14 % (U _N) , 300 Hz			
	Comments	Criterion B	Criterion A			
Attenuated oscillating wave EN 61000	-4-18					
	Input, Output	1 MHz 0.5 kV (Test Level 2 - symmetrical)	100 kHz , 1 MHz , 1 kV (Test Level 3 - symmetrical)			
		1 MHz , 1 kV 10 MHz 0.5 kV (Test Level 2 - asymmetrical)	100 kHz , 1 MHz , 1 kV 10 MHz , 0.5 kV (Test Level 2 - asymmetrical)			
	Signals	1 MHz , 0.5 kV (Test Level 2 - symmetrical)	100 kHz , 1 MHz , 0.5 kV (Test Level 2 - symmetrical)			
		1 MHz , 1 kV (Test Level 2 - asymmetrical)	100 kHz , 1 MHz , 1 kV (Test Level 2 - asymmetrical)			
	Comments	Criterion B	Criterion A			
Voltage dips EN 61000-4-29						
Input voltage (24 V DC)						
	Voltage dip	70~% , 100 ms (Test Level 2)	70~% , $100~ms$ (Test Level 2)			
	Comments	Criterion C	Criterion A			
	Voltage dip	40~% , $100~ms$ (Test Level 2)	40 % 100 ms (Test Level 2)			
	Comments	Criterion C	Criterion A			
	Voltage dip	0 % , 50 ms (Test Level 2)	0 % , 50 ms (Test Level 2)			
	Comments	Criterion B	Criterion B			
Кеу						
Criterion A	Normal operating b	pehavior within the specified limit	ts.			
Criterion B	Temporary impairm	nent to operational behavior that	is corrected by the device itself.			
Criterion C		e effects on the operating behav hich can be restored by actuating				

109371_en_00

PHOENIX CONTACT 14/49

5 Safety and installation notes

5.1 Symbols used

Instructions and possible hazards are indicated by corresponding symbols in this document.



This is the safety alert symbol. It is used to alert you to potential personal injury hazards. Obey all safety measures that follow this symbol to avoid possible personal injuries.

There are different categories of personal injury that are indicated by a signal word.



WARNING

This indicates a hazardous situation which, if not avoided, could result in death or serious injury.



CAUTION

This indicates a hazardous situation which, if not avoided, could result in minor or moderate injury.



WARNING: Explosion hazard

This is the safety alert symbol. It is used to alert you to potential personal injury hazards. Obey all safety measures that follow this symbol to avoid possible personal injuries.

The following symbols are used to indicate potential damage, malfunctions, or more detailed sources of information.




NOTE

This symbol together with the signal word NOTE and the accompanying text alert the reader to a situation which may cause damage or malfunction to the device, hardware/software, or surrounding property.



This symbol and the accompanying text provide the reader with additional information or refer to detailed sources of information.

5.2 Safety and warning notes



- Only skilled persons may install, start up, and operate the device.
- The power supply must be switched off from outside (e.g. via the line protection on the primary side).
- Never carry out work when voltage is present.
- Establish connection correctly and ensure protection against electric shock.
- Cover termination area after installation in order to avoid accidental contact with live parts (e.g., installation in control cabinet).



CAUTION: Hot surface

Depending on the ambient temperature and load on the power supply, the housing can become hot.



- Observe the national safety and accident prevention regulations.
- Assembly and electrical installation must correspond to the state of the art.
- The power supply is a built-in device and is designed for mounting in a control cabinet.
- The IP20 degree of protection of the device is intended for use in a clean and dry environment.
- Observe mechanical and thermal limits.
- Ensure minimum clearances to external heat sources.
- Mount the power supply unit in the standard installation position.
- Ensure that the primary-side wiring and secondary-side wiring are the correct size and have sufficient fuse protection.
- Use copper cables for operating temperatures of >75 °C (ambient temperature <55 °C)
 >90 °C (ambient temperature <75 °C).
- For the connection parameters for wiring the power supply, such as the required stripping length with and without ferrule, refer to the technical data section.
- Protect the device against foreign bodies penetrating it, e.g., paper clips or metal parts.
- The power supply is maintenance-free. Repairs may only be carried out by the manufacturer. The warranty no longer applies if the housing is opened.
- The power supply may only be used for its intended use.

 Relay contact 13/14 can be used to max. 30 V AC/ 24 V DC.



WARNING: Explosion hazard


- Equipment shall be installed in appropriate
 IP54 enclosure according EN 60079-0 and EN 60079-7.
- This is assured with enclosure in type of protection Ex ec or Ex eb.
- The installation in the enclosure must be carried out in such a way that the ambient temperature is not exceeded during operation.
- The distance to other components or enclosure's wall shall be at least 15 mm (left, right) and 50 mm (top, bottom).
- The equipment shall only be used in an area of at least pollution degree 2, as defined in IEC 60664-1.
- The equipment shall be used in clean dry conditions.
- Enclosure of the equipment shall be earthed by installation on earthed DIN Rail.
- The category 3 device is suitable for installation in zone 2 potentially explosive areas in accordance with directive 2014/34/EU.
- The device is not designed for use in dust explosion hazardous atmosphere.



The continuous total output power may not exceed P_N at 60 °C ambient temperature and $P_{Stat. Boost}$ at 40°C ambient temperature. Observe all the maximum output powers for all operating conditions.

NOTE: Damage to the Push-in connection terminal blocks is possible

Do not plug test pins into the Push-in connection terminal blocks. The maximum pluggable depth of the Push-in connection terminal blocks is limited. In addition, when the test pin is plugged in, the unlocking button (pusher) is covered to such an extent that unlocking is not possible or only possible to an insufficient extent. If you do not push the unlocking button (pusher) down completely when you are pulling the test pin out, then the Push-in connection terminal block will become damaged.



6 High-voltage test (HIPOT)

This power supply is subject to the Low Voltage Directive and is factory tested. During the HIPOT test (high-voltage test), the insulation between the input circuit and output circuit is tested for the prescribed electric strength values, for example. The test voltage in the high-voltage range is applied at the input and output terminal blocks of the power supply. The operating voltage used in normal operation is considerably lower than the test voltage used.

6.1 High-voltage dielectric test (dielectric strength test)

In order to ensure permanent safe isolation of the DC input circuit and DC output circuit, high-voltage testing is performed as part of the safety approval process (type test) and manufacturing (routine test).

6.2 High-voltage dielectric test during the manufacturing process

During the manufacturing process for the power supply, a high-voltage test is performed as part of the dielectric test in accordance with the specifications of IEC/UL/EN 61010-1. The high-voltage test is performed with a test voltage of at least 2 kV DC or higher. Routine manufacturing tests are inspected regularly by a certification authority.

6.3 High-voltage dielectric test performed by the customer

Apart from routine and type tests to guarantee electrical safety, the end user does not have to perform another highvoltage test on the power supply as an individual component. According to EN 60204-1 (Safety of machinery - Electrical equipment of machines) the power supply can be disconnected during the high-voltage test and only installed once the high-voltage test has been completed.

6.3.1 Performing high-voltage testing

If high-voltage testing of the control cabinet or the power supply as a stand-alone component is planned during final inspection and testing, the following features must be observed.

- The power supply wiring must be implemented as shown in the wiring diagram.
- The maximum permissible test voltages must not be exceeded.

Avoid unnecessary loading or damage to the power supply due to excessive test voltages.




For the relevant applicable test voltages and insulation distances, refer to the corresponding table (see technical data: electric strength of the insulation section).

109371_en_00

Figure 1 Pc

Potential-related wiring for the high-voltage



Key


No.	Designation	Color coding	Potential lev- els
1	DC output circuit	Blue	Potential 1
2	Signal contacts	Blue	Potential 1
3	High-voltage tester		
4	DC input circuit	Red	Potential 2

7 Structure of the power supply

The fanless convection-cooled power supply can be snapped onto all DIN rails according to EN 60715.

7.1 Function elements

Figure 2 Operating and indication elements



Key

No.	Designation
1	DC output voltage connection terminal blocks
2	Accommodation for cable binders
3	Signaling connection terminal blocks
4	Status and diagnostics indicators
5	Position NFC interface (Near Field Communication)
6	QR code web link
7	DC input voltage connection terminal blocks
8	Universal DIN rail adapter (rear of housing)
9	Output voltage button ↓(-) / ↑(+)

7.2 Device dimensions

Figure 3 Device dimensions (dimensions in mm)





Figure 4


Device dimensions (dimensions in mm)



7.3 Keep-out areas


Nominal output	Spacing [mm]				
capacity	а	b	С		
< 50 %	0	40	20		
≥ 50 %	5	50	50		

Figure 5 Device dimensions and minimum keep-out areas (in mm)



7.4 Block diagram

Figure 6 Block diagram



Key

Symbol	Designation
₽	Surge protection (varistor) with filter
	Reverse polarity protection
	Inrush current limitation
	Switching transistor and main transmitter (electrically isolating)
*	Secondary rectification and smoothing
	Filter
	Auxiliary converter (electrically isolating)
)=¥	Optocoupler (electrically isolating)


Symbol	Designation
OVP	Additional regulatory protection against surge voltage
$\left[\right]$	Switch
-	PNP transistor switch output
μ	Microcontroller
)))NFC)))	Passive NFC interface (Near Field Communi- cation)
, ,	Output voltage button ∛ (-) / † (+)
¥*	Signal/display LEDs


8 Mounting/removing the power supply

8.1 Mounting the power supply unit

Proceed as follows to mount the power supply:

- 1. In the normal mounting position the power supply is mounted on the DIN rail from above. Make sure that the universal DIN rail adapter is in the correct position behind the DIN rail (A).
- 2. Then press the power supply down until the universal DIN rail adapter audibly latches into place (B).
- 3. Check that the power supply is securely attached to the DIN rail.






8.2 Removing the power supply unit

Proceed as follows to remove the power supply:

- 1. Take a suitable screwdriver and insert this into the lock hole on the universal DIN rail adapter (A).
- 2. Release the lock by lifting the screwdriver (B).
- 3. Carefully swivel the power supply forward (C) so that the lock slides back into the starting position.
- 4. Then separate the power supply from the DIN rail (D).
- Figure 8 Removing the power supply from the DIN rail





8.3 Retrofitting the universal DIN rail adapter

For installation in horizontal terminal boxes it is possible to mount the power supply at a 90° angle to the DIN rail. No additional mounting material is required.




Use the Torx screws provided to attach the universal DIN rail adapter to the side of the power supply.

8.3.1 Disassembling the universal DIN rail adapter

Proceed as follows to disassemble the universal DIN rail adapter that comes pre-mounted:

- 1. Remove the screws for the universal DIN rail adapter using a suitable screwdriver (Torx 10).
- 2. Separate the universal DIN rail adapter from the rear of the power supply.

Figure 9 Disassembling the universal DIN rail adapter



8.3.2 Mounting the universal DIN rail adapter

To mount the universal DIN rail adapter on the left side of the device, proceed as follows:

- 1. Position the universal DIN rail adapter on the left side of the housing so that the mounting holes are congruent with the hole pattern for the mounting holes.
- 2. Insert the Torx screws that were removed earlier into the appropriate hole pattern on the universal DIN rail adapter so that the necessary drill holes on the power supply can be accessed.
- 3. Screw the universal DIN rail adapter onto the power supply.

i

The maximum tightening torque of the Torx screw (Torx® T10) is 0.7 Nm.




Figure 10 Mounting the universal DIN rail adapter

8.4 Retrofitting the universal wall adapter

The UWA 182/52 universal wall adapter (Order No. 2938235) or UWA 130 universal wall adapter (Order No. 2901664) is used to attach the power supply directly to the mounting surface.

The use of universal wall adapters is recommended under extreme ambient conditions, e.g., strong vibrations. Thanks to the tight screw connection between the power supply and the universal wall adapter or the actual mounting surface, an extremely high level of mechanical stability is ensured.





The power supply is attached to the UWA 182 or UWA 130 universal wall adapter by means of the Torx screws of the universal DIN rail adapter.

8.4.1 Mounting the UWA 182/52 universal wall adapter

Proceed as follows to disassemble the universal DIN rail adapter that comes pre-mounted:

- 1. Remove the screws for the universal DIN rail adapter using a suitable screwdriver (Torx 10).
- 2. Separate the universal DIN rail adapter from the rear of the power supply.
- 3. Position the universal wall adapter in such a way that the keyholes or oval tapers face up. The mounting surface for the power supply is the raised section of the universal wall adapter.
- 4. Place the power supply on the universal wall adapter in the normal mounting position (input voltage connection terminal blocks below).
- 5. Insert the Torx screws into the appropriate hole pattern on the universal wall adapter so that the necessary mounting holes on the power supply can be accessed.
- 6. Screw the universal wall adapter onto the power supply.







The maximum tightening torque of the Torx screw (Torx T10) is 0.7 Nm.




Make sure you use suitable mounting material when attaching to the mounting surface.

8.4.2 Mounting the UWA 130 2-piece universal wall adapter

Proceed as follows to disassemble the universal DIN rail adapter that comes pre-mounted:

- 1. Remove the screws for the universal DIN rail adapter using a suitable screwdriver (Torx 10).
- 2. Separate the universal DIN rail adapter from the rear of the power supply.
- 3. Position the universal wall adapter. The mounting surface for the power supply is the raised section of the universal wall adapter.
- 4. Place the power supply on the universal wall adapter in the normal mounting position (input voltage connection terminal blocks below).
- 5. Insert the Torx screws into the appropriate hole pattern on the universal wall adapter so that the necessary mounting holes in the side flanges of the power supply can be accessed.
- 6. Screw the two-piece universal wall adapter onto the power supply.

Figure 12 Mounting the UWA 130 universal wall adapter




8.5 Fix connection wiring to the power supply

Two receptacles for the bundled attachment of the connection wiring are integrated in the left and right housing panel. Use cable binders to secure the connection wiring (optional PKB 140X3,6 - Order No. 1005460).

Proceed as follows to secure the connection wiring:


- Wire the power supply with sufficient connection reserve (input terminal blocks, output terminal blocks, signal terminal blocks)
- Bundle and set up the connection wiring so that the cooling grilles on the top and bottom of the housing are covered as little as possible.
- Thread the cable binders into the necessary receptacles for the cable binders.

Figure 13 Lay and align connection wiring




 Secure the connection wiring with the cable binders.
 Make sure that the connection wiring is attached safely and securely without damaging the connection wiring.

Figure 14 Secure connection wiring with cable binder



- Shorten the excess length of the cable ties.
- Then check again that the connection wiring is properly secured.

Figure 15 Shorten protruding ends of the cable binder





NOTE: Mechanical damage to the connection wiring caused by friction

In extreme ambient conditions, e.g., strong vibrations, protect the connection wiring against mechanical damage using additional insulation material. The additional insulation material for protecting the connection wiring is limited to the area where the cable binders are attached.

9 Device connection terminal blocks

The front-mounted DC input and DC output terminal blocks and the signal terminal blocks of the power supply feature Push-in connection technology. The wiring is performed by plugging in, without tools.



For the necessary connection parameters for the connection terminal blocks, refer to the technical data section.

9.1 Input


The power supply is connected on the primary side via the Input +/- connection terminal blocks.

9.2 Protection of the primary side

Installation of the device must correspond to EN 61010 regulations. It must be possible to switch off the device using a suitable disconnecting device outside the power supply. The line protection on the primary side is suitable for this (see technical data section).

Protection

Figure 16 Pin assignment for DC supply voltage



DC applications require upstream installation of a fuse that is permitted for the operating voltage.

9.3 Output

By default, the power supply is pre-set to a nominal output voltage of 24 V DC.

The output voltage is adjusted via the two arrow keys \downarrow (-) and \ddagger (+) on the front of the power supply.

When you press the arrow key once briefly, the output voltage is reduced $\P(-)$ or increased $\uparrow(+)$ by 3 mV. When you press the arrow key for longer, the voltage is adjusted in 100 mV increments.

9.4 Protection of the secondary side

The power supply is electronically short-circuit-proof and no-load-proof. In the event of an error, the output voltage is limited

•

If sufficiently long connecting cables are used, fuse protection does not have to be provided for each individual load.

If each load is protected separately with its own protective device, the selective shutdown in the event of a fault enables the system to remain operational.

10 Output characteristic curves

This section describes the various output characteristic curves together with their areas of application for customization to your specific application. The U/I Advanced characteristic curve is set by default.

ApplicationNormal loadSystem extensionLoads with high inrush currentEnergy storage chargingSelective tripping of fusesKeeps temperatures low in the event of faultsShort circuit, non-fusedYour benefitsReliable power supplyA stable 24 V, even in the event of a sustained overloadNo over-dimensioned power supply unit requiredFast chargingParallel loads continue workingLow thermal stress in the even of faultsEnables configuration without fuse		ļ	\otimes	M	+ -		X
Your benefits Reliable power supply event of a sustained power supply unit power supply unit Fast charging Parallel loads continue Low thermal stress in Enables configuration without fuse	Application	Normal load	System extension	-	Energy storage charging	 low in the event of	Short circuit, non-fused
	Your benefits		event of a sustained	power supply unit	Fast charging		

U/I Advanced	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	_
Smart HICCUP	✓	\checkmark	✓	\checkmark	—	\checkmark	—
FUSE MODE	\checkmark	\checkmark	—	—	—	\checkmark	\checkmark

Symbol	Designation
\checkmark	Suitable for the application
-	Not suitable for the application

10.1 U/I Advanced output characteristic curve

The preset U/I Advanced output characteristic curve is optimized for the following applications:

- For selective tripping of standard circuit breakers (SFB technology). The power supply supplies up to 6 times the nominal current for 15 ms. Loads connected in parallel continue working.
- When supplying loads with high switch-on currents, such as motors. The dynamic boost of the power supply supplies up to 200% of the nominal power for 5 s. This ensures that sufficient reserve energy is available; overdimensioning of the power supply is not necessary.
- For system extension. With the static boost, up to 125% of the nominal output power is available for a sustained period (up to 40°C).
- For fast energy storage charging (e.g., of batteries) to supply a wide range of loads. The power supply operates in the nominal operating range. Energy supply to the load is ensured.




Figure 17 U/I Advanced output characteristic curve


10.2 Smart HICCUP output characteristic curve

The SMART HICCUP output characteristic curve keeps the thermal load of the connecting cables at a low level in the event of a sustained overload. If loads are not protected or are protected in a way that is not permitted, the loads are supplied for 2 s. The DC output of the power supply is then switched off for 8 s. This procedure is repeated until the cause of the overload has been remedied.

The preset Smart HICCUP output characteristic curve is optimized for the following applications:

- If only a low short-circuit current is permitted.
- If following an overload or short circuit the output voltage should be made available again automatically.

Figure 18 Smart HICCUP output characteristic curve




10.3 FUSE MODE output characteristic curve

In the event of an overload (e.g., short circuit), the power supply switches off the DC output permanently. The value of the switch-off threshold and the time period for which it may be exceeded can be freely selected. The power supply is restarted via the remote contact. As an option, the power supply can be switched on by switching the supply voltage on the primary side off and on.

Selecting the FUSE MODE output characteristic curve sets the following default values.

- t_{Fuse} = 100 ms
- I_{Fuse} = I_N

Figure 19 FUSE MODE output characteristic curve



11 Configuring the power supply

With the fourth generation of the QUINT POWER power supply, it is now possible for the first time to adapt the behavior of the power supply. In addition to setting the output voltage and selecting the output characteristic curves, you can configure signal outputs Out 1, Out 2, and floating signal contact 13/14, for example. Configuration of the remote input for controlling the power supply or specification of signal options and signal thresholds also extend the range of possible applications.

The power supply is configured via the device's internal NFC (near field communication) interface. This is located behind the QR code on the front.



The power supply behaves like a passive NFC tag. An auxiliary power source is required in order to supply the power supply with configuration data.

11.1 Configuration with PC software

In order to configure the power supply via the NFC interface, the following hardware and software requirements must be met:


- PC or notebook (as of Windows 7, Microsoft.Net Framework 4.5, USB 2.0 interface, 50 MB hard disk capacity, QUINT POWER software).
- Programming adapter: TWN4 MIFARE NFC USB ADAPTER (Order No. 2909681) is plugged into the USB interface.
- Programming software: the QUINT POWER software has been successfully installed.

11.2 Configuring the power supply


To configure the power supply, proceed as follows:


- Before you can configure the power supply, it should either be disconnected from the supply voltage or switched to SLEEP MODE.
- To switch the power supply to SLEEP MODE, use one of the external circuits. The following connection versions are possible between the Rem (remote input) and SGnd (signal ground) connection terminal blocks.

Figure 20	SLEEP MODE connection versions
-----------	--------------------------------



 Hold the USB-PROG-ADAPTER in front of the mounted power supply such that the NFC antenna symbol is over the QR code.





 In the programming interface of the QUINT POWER software, press the [Read] button. The current device and configuration data for the power supply is read and displayed.



If a connection cannot be established between the USB-PROG-ADAPTER and the power supply, more detailed information can be found in the user manual for the QUINT POWER software.



For information regarding the configuration of the power supply, such as selecting the characteristic curve and output parameters, refer to the user manual for the QUINT POWER software.

11.3 Configuration with NFC-capable mobile terminal device

The QUINT POWER app enables you to conveniently configure the power supply using a mobile terminal device, such as a smartphone.

In order to configure the power supply via the NFC interface, the following hardware and software requirements must be met:

- NFC-capable mobile terminal device with Android operating system as of Version 4.1.x (Jelly Bean)
- QUINT POWER app (Google Play Store)




For information regarding the configuration of the power supply, such as selecting the characteristic curve and output parameters, please refer to the QUINT POWER app.


12 Boost currents

The power supply provides the static boost ($I_{Stat. Boost}$) for a sustained load supply or the time-limited dynamic boost ($I_{Dyn. Boost}$).

12.1 Static Boost

For system expansion purposes, the sustained static boost ($I_{Stat. Boost}$) supports the load supply with up to 125 % of the nominal current of the power supply. The static boost is available at an ambient temperature of up to 40 °C.






12.2 Dynamic Boost

Dynamic boost ($I_{Dyn. Boost}$) delivers up to 200 % of the power supply nominal current to supply high loads. This temporary power supply to the load lasts a maximum of 5 s at an ambient temperature of up to 60 °C. The energy supplied adaptively for the load supply and the recovery time (t_{Pause}) are calculated based on the specific load situation using algorithms (see recovery time tables).

Figure 23 Basic curve of the dynamic boost process



Use the following tables to determine the required recovery time (t_{Pause}) at the maximum dynamic boost current ($I_{Dyn.}$ Boost) based on the following values:

- I_{Base Load}
- Duration of the boost current (t_{Dyn. Boost})
- Ambient temperature (40 °C or 60 °C)



If a current that is lower than the maximum available dynamic boost current ($I_{Dyn. Boost}$) is required for the same period, the recovery time may (t_{Pause}) decrease.

12.2.1 Recovery times at an ambient temperature of 40 $^\circ\text{C}$

I _{Base Load}	I _{Dyn. Boost}		t _c	yn. Boost [s]]
[A]	[A]	1	2	3	4	5	
0	10	1,7	3,3	5	6,7	8,3	
1	10	1,8	3,6	5,4	7,2	9	
2	10	2	4	6	8	10	
3	10	2,4	4,8	7,2	9,6	12	t _{Pause} [s]
4	10	4,1	6,8	10,3	12,6	16,1	╵┶┸
5	10	5,2	8,7	13,3	21,7	26,2	
6,25	10	11	23,5	35,6	41,3	50,5	

Figure 24 Required recovery times at $\leq 40^{\circ}$ C

12.2.2 Recovery times at an ambient temperature of 60 °C

Figure 25 Required	d recovery times at $\leq 60^{\circ}$ C
--------------------	---

I _{Base Load}	I _{Dyn. Boost}		tc	Dyn. Boost [s]		
[A]	[A]	1	2	3	4	5	
0	10	2,5	4,8	7,3	9,7	12,3	
1	10	3	6,4	9,3	12,5	15,4	
2	10	3,5	7,8	11,1	13,8	17,3	S
3	10	4,7	9	13,5	18,5	23	t _{Pause} [s]
4	10	7,5	13,5	20	26,3	32,1	
5	10	23	45	66	80	91	

12.2.3 Example: Determining the recovery time (t_{Pause})

At an output current ($I_{Base Load}$) of 2 A, the dynamic output current ($I_{Dyn. Boost}$) of 10 A increases for 3 s ($t_{Dyn. Boost}$). After a recovery time (t_{Pause}) of 6 s, the dynamic boost is available once again.

I _{Base Load}	Base Load I _{Dyn. Boost}						
[A]	[A]	1	2	3	4	5	
0	10	1,7	3,3	5	6,7	8,3	
1	10	1,8	3,6	5,4	7,2	9	
2	10	2	4	6	8	10	_
3	10	2,4	4,8	7,2	9,6	12	t _{Pause} [s]
4	10	4,1	6,8	10,3	12,6	16,1	T.
5	10	5,2	8,7	13,3	21,7	26,2	
6,25	10	11	23,5	35,6	41,3	50,5	

Figure 26 Example recovery time for $\leq 40^{\circ}$ C

13 SFB Technology

SFB Technology (selective fuse breaking) can be used to quickly and reliably trip miniature circuit breakers and fuses connected on the secondary side. In the event of a short circuit on the secondary side, the power supply supplies up to 6 times the nominal current for 15 ms. The faulty current path is switched off selectively.

Loads that are connected in parallel are still supplied with energy. Operation of these system parts is ensured. In order to always enable the reliable tripping of circuit breakers and fuses, certain framework conditions must be observed (see SFB configuration section).




The U/I Advanced output characteristic curve supports SFB Technology.

13.1 Tripping circuit breakers

The circuit breaker is tripped by the high SFB current of the power supply, typically within 3 to 5 ms. As a result, voltage dips at loads that are connected in parallel are avoided.

Figure 27 SFB pulse trips circuit breakers




13.2 Tripping a fuse

Fuses are tripped by melting the predetermined breaking point inside the fuse capsule. The tripping characteristic of the fuse is described by the melting integral (l²t). A high current is crucial in order to achieve a very short tripping time.

13.3 SFB configuration

Observe the following framework conditions for determining the maximum distance between the power supply and load:

- The performance class of the power supply
- The cross section of the connecting cable
- The tripping characteristic of the fuse component
- Figure 28 Schematic diagram of the maximum cable length



13.4 Maximum distance between the power supply and load

The distances given in the table are worst-case values and therefore cover the entire tolerance range for the magnetic tripping of circuit breakers. The possible distances are often greater in practice.

13.4.1 Thermomagnetic device circuit breaker, type: Phoenix Contact CB TM1 SFB

Maximum distance I [m] with device circuit breaker		Conductor of	Conductor cross section				
		A [mm ²]	0.75	1.0	1.5	2.5	
		AWG	18	(17)	16	14	
Phoenix Contact	CB TM1 1A SFB P		27	36	54	91	
	CB TM1 2A SFB P		10	13	20	34	

The cable lengths determined are based on the following parameters:

Tripping:	magnetic
DC correction factor (0 Hz):	Phoenix Contact = 1,0
Characteristics:	С
	Characteristic C (10 times the rated current) x correction factor
Ambient temperature:	+20 °C
Internal resistance R _i of the device circuit breaker:	taken into consideration
Comments:	In addition to the short-circuit current, the power supply unit also supplies half the nominal current for load paths connected in parallel.

Maximum distance I [m	n] with circuit breaker	Conductor of	cross sect	ion		
		A [mm ²]	0.75	1.0	1.5	2.5
		AWG	18	(17)	16	14
Siemens 5SY	A1		78	105	157	263
	A1.6		58	77	116	194
	A2		49	65	98	164
	A3		35	47	70	118
	A4		20	27	40	68
	B2		24	33	49	82
	C1		7	9	14	24
	C1.6		3	5	7	13
	C2		3	4	6	10
ABB S200	C2		1	1	2	4
	Z1		64	85	128	214
	Z1.6		46	62	93	156
	Z2		42	57	85	143
	Z3		30	41	61	102
	Z4		17	23	34	57

13.4.2 Thermomagnetic circuit breaker, type: Siemens 5SY, ABB S200

The cable lengths determined are based on the following parameters:

Tripping:	magnetic
DC correction factor (0 Hz):	Siemens = 1.4; ABB = 1.5
Characteristics:	A, B, C, Z
	Characteristic A (3 times the rated current) x correction factor
	Characteristic B (5 times the rated current) x correction factor
	Characteristic C (10 times the rated current) x correction factor
	Characteristic Z (3 times the rated current) x correction factor
Ambient temperature:	+20 °C
Internal resistance R _i of the device circuit breaker:	taken into consideration
Comments:	In addition to the short-circuit current, the power supply unit also supplies half the nominal current for load paths connected in parallel.

13.4.3 Fuse, type: Cooper Bussmann GMA xA, GMC xA

Maximum distance I [m] with fuse		Melting integral I ² t [A ² s]	Conductor	cross se	ection		
			A [mm ²]	0.75	1.0	1.5	2.5
			AWG	18	(17)	16	14
Cooper Bussmann	GMA 1A	0.48	0.48		64	97	162
	GMA 1.25A	0.84		36	48	72	120
	GMA 1.5A	1.6		19	25	38	64
	GMA 1.6A	2		15	20	31	51
	GMA 2A 3.1			9	13	19	33
	GMC 1A	1.8	1.8		20	31	52
	GMC 1.25A	3.4		8	11	16	27

The cable lengths determined are based on the following parameters:

Tripping:thermalCharacteristics:Cooper Bussmann GMA (fast-blow - fast acting)
Cooper Bussmann GMC (medium-blow - medium time delay)Ambient temperature:+20 °CInternal resistance R_i of the fuse:taken into considerationComments:In addition to the short-circuit current, the power supply unit also supplies
half the nominal current for load paths connected in parallel.

14 Signaling

A floating signal contact and two digital outputs are available for preventive function monitoring of the power supply.


Depending on the configuration of the power supply, either the two digital outputs or one digital and one analog output can be selected. The signal outputs are electrically isolated from the input and output of the power supply.


Five LED status indicators signal the current device status. The function of each LED status indicator is assigned to a fixed event.

In addition, the power supply can be switched off and on via an external circuit.

The signal outputs are configured on the software side using the QUINT POWER software or the QUINT POWER app. Upon delivery, the power supply is pre-allocated a default configuration for the signal outputs.

14.1 Location and function of the signaling elements






Key

No.	Signaling elements
1	13/14 floating switch contact (N/O contact)
2	Rem, remote input (switch power supply off and on)
3	SGnd, signal ground (reference potential for signals Out 1, Out 2)
4	Out 1 (digital output, function depends on the signal option set)
5	Out 2 (digital or analog output, function depends on the signal option set)
6	LED status indicator U _{In} OK
	LED off: U _{In} > 80 % x U _{InNom}
	LED on: U _{In} < 80 % x U _{InNom}
7	LED status indicator DC OK
	LED on: U _{Out} > 90% x U _{Set}
	LED flashing: U _{Out} < 90 % x U _{Set}
8	LED status indicator P _{Out} >50% (out-
	put power >60 W)
9	LED status indicator P _{Out} >75% (out-
	put power >90 W)
10	LED status indicator P _{Out} >100%, boost mode (out-
	put power >120 W)

14.1.1 Floating signal contact

In the default configuration, the floating switch contact opens to indicate that the set output voltage has been undershot by more than 10 % ($U_{Out} < 0.9 \times U_N$). Signals and ohmic loads can be switched. For heavily inductive loads (e. g. a relay), a suitable protective circuit (e. g. a freewheeling diode) is necessary.

Figure 30 Signaling



14.1.2 Active signal outputs, digital


Signals are forwarded to the higher-level controller via the "Out 1" and "Out 2" signal outputs.

The 24 V DC signal is applied between the connection terminal blocks "Out 1" and "SGnd" or between "OUT 2" and "SGnd". It can carry a maximum of 20 mA.

In standard configuration, the "Out 1" signal output indicates by changing from "Active Low" to "Active High" that the nominal input voltage has dropped below 20 % ($U_{In} < 0.8 \times U_{InNom}$).

In the default configuration, the signal output "Out 2" indicates that the nominal power has been exceeded. The power supply then switches to boost mode. Thanks to this preventive function monitoring, critical operating states can be recognized at an early stage, prior to a voltage dip occurring.






14.1.3 Active analog signal output

The signal output "Out 2" can be used as an analog signal output to continuously monitor the device workload.

The 4 ... 20 mA signal is applied between the connection terminal blocks "Out 2" and "SGnd". It is proportional to the set signaling parameter.





14.2 Preventive function monitoring

In contrast to the default signaling set upon delivery, you can customize this to the specific needs of the system. The following signal options can be selected to signal system states.

QUINT POWER default settings upon delivery			Out 1 digital 0/24 V DC 20 mA	Out 2 digital 0/24 V DC 20 mA	Relay 13/14 floating 24 V DC / ≤ 1 A 30 V AC / ≤ 0.5 A	Out 2 analog 4 20 mA
	Output voltage	1) 25 135 % 2) 90 %	~	~	Default	1 0 32,5 V 2 0 30 V
Â	Output current	1 5 150 % 2 100 %	\checkmark	\checkmark	\checkmark	1 0 10 A 2 0 5 A
P	Output power	 1 5 200 % 2 100 % 	~	Default	\checkmark	1 0 240 W 2 0 120 W
0 0 0 h	Operating hours	① 0 ∞ h ② 10 years	\checkmark	\checkmark	~	
θ	Early warning of high temperature	Warning of derat- ing	\checkmark	\checkmark	~	
OVP	Voltage limitation active	Surge voltage at output	~	~	\checkmark	
U _{In}	Input voltage OK		Default		~	

Key

Symbol	Description
1	Setting range
2	Default setting of the standard item
Default	Configuration set upon delivery
\checkmark	Configuration that can be selected
	Configuration that cannot be selected

The simultaneous control of multiple signal outputs by means of one signal option is possible, as is the use of logic operations to link multiple signal options to one control. The power supply is configured using the QUINT POWER software or the QUINT POWER app.

14.3 Description of signaling

14.3.1 Output voltage

Signals whether the output voltage is in the preset range. If the output voltage of the power supply falls below the set threshold value, the signal state changes.

Example of use

Indicates whether the connected load is being supplied. Used to quickly detect a load circuit that is not being supplied (e.g., in the event of mains failure or short circuit in the supply line).

14.3.2 Output current

If the output current of the power supply exceeds the set threshold value, the signal state changes.

Example of use

In the case of system extensions, loads are added. This increases the utilization of the power supply. Preventive function monitoring detects critical operating states in good time. Action can be taken before system downtime occurs.

14.3.3 Output power

If the output power of the power supply exceeds the set threshold value, the signal state changes.

Example of use

In the case of system extensions, loads are added. This increases the utilization of the power supply. Preventive function monitoring detects critical operating states in good time. Action can be taken before system downtime occurs.

14.3.4 Operating hours

If the preset operating time of the power supply is exceeded, the signal state changes.

Example of use

For systems with a very long operating time, such as wind turbine generators or refineries, maintenance intervals are planned. You can even schedule the maintenance date during configuration based on the ambient temperature and utilization of the power supply.

14.3.5 Early warning of high temperature

Before the power supply protects itself through power derating in the event of an overtemperature, the signal state changes.

Example of use

Outdoor control cabinets can reach a high internal temperature depending on the position of the sun. The same

is true if a control cabinet fan or cooling system fails. In the event of any form of overtemperature, the power supply provides a warning by means of this signal, well before the supply of the loads is in any danger.

Specifications regarding the available output power (see derating section).

14.3.6 Voltage limitation active

If the circuit inside the device for protecting against surge voltages is activated at the output, the signal state changes.

Example of use

Normative requirements stipulate that an upper voltage limit must be observed at the output in the event of an error. It must therefore be ensured, for example, that safety-related controllers are not supplied with an output voltage that exceeds 32 V DC, even in the event of an error. If foreign bodies (ferrules, screws, etc.) enter the power supply and generate an error, the signal state changes.

14.3.7 Input voltage OK

Signals whether the input voltage is in the preset range. If the input voltage of the power supply falls below the set threshold value, the signal state changes.

Example of use


Indicates whether the power supply is being fed accordingly. Used to quickly detect undershooting of the input voltage.

14.4 Remote input

The power supply is switched on and off using the digital remote input of the power supply. When switched off, power transmission is deactivated on the DC output side of the power supply. The load connected to the DC output terminal blocks is no longer supplied with energy. The operating mode where the DC output side is deactivated is called SLEEP MODE.


To switch the power supply to SLEEP MODE, select one of the external circuit versions below. The external circuit is wired between signal terminal blocks Rem (remote input) and SGnd (signal ground).

Figure 33 External wiring versions, enable SLEEP MODE




To switch the power supply back on, select one of the following external circuits between signal terminal blocks Rem and SGnd. Power transmission inside the device is activated again. As usual, the energy for supplying the loads is available at the DC output terminal blocks.

Figure 34 External wiring versions, disable SLEEP MODE



When using a PLC output, select the following external circuit version to switch the power supply to SLEEP MODE.

Figure 35 External wiring versions with PNP and NPN output



14.5 LED status indicators

Five LED status indicators on the front of the DC/DC converter inform you about the current device status.

The green DC OK LED indicates the current status of the output voltage (U_{Out}). The DC OK LED is permanently on as long as the value of the output voltage U_{Out} is \geq 0.9 x U_{Set}. If the value of the output voltage is < 0.9 x U_{Set}, the green DC OK LED flashes.

The yellow U_{In} LED indicates the current status of the input voltage (U_{In}). The U_{In} LED lights up as soon as the value of input voltage (U_{In}) drops below U_{In} < 0.8 x U_{InNom}.

Depending on the required output power of the connected load, the three P_{Out} LEDs, which indicate the current output power, light up. Assuming that the provided output power is > 50% of the nominal output power, the > 50% LED lights up green. If the demanded power continues to increase until it is above 75%, the > 75% LED lights up green in addition to the > 50% LED. If the required output power is then greater than the nominal device power, the power supply operates in boost mode. In boost mode, the > 100% LED additionally lights up yellow.

14.6 U/I Advanced characteristic curve signaling

The following table shows the standard assignment for signaling for the U/I Advanced characteristic curves which is set by default.




Figure 36 Signal image for U/I Advanced

14.7 SMART HICCUP characteristic curve signaling

The following table shows the standard assignment for signaling for the SMART HICCUP characteristic curve.

Figure 37 Signal image for SMART HICCUP

		Normal operation P _{Out} < P _N	BOOST P _{out} > P _N	Overload operation U _{Out} < 0.9 x U _{Set}	Input voltage < 0.8 x U _N
LED: P _{Out} >100 % Yellow					х
Signal Out 2: P _{Out} < P _N Default		Active High	Active Low	Active Low	х
LED: P _{Out} > 75 %					х
LED: P _{Out} > 50 %	Green				х
LED: DC OK					х
LED: U _{in} <19,2 V	Yellow	х	х	х	
Relay: 13/14, DC OK	Default	Closed	Closed	Open	х
Signal Out 1: U _{in} <19,2 V	Deiduit	Active High	Active High	Active High	Active Low
LED Off LED On - LED Flashing X Not relevant					

14.8 FUSE MODE characteristic curve signaling

The following table shows the standard assignment for signaling for the FUSE MODE characteristic curve.

		Normal operation P _{Out} < P _N	BOOST P _{out} > P _N	FUSE MODE	Input voltage < 0.8 x U _N
LED: P _{Out} >100 % Yellow					X
Signal Out 2: P _{Out} < P _N	Default	Active High	Active Low	Active Low	х
LED: P _{Out} > 75 %					х
LED: P _{Out} > 50 %	Green			-	х
LED: DC OK				-	х
LED: U _{in} <19,2 V	Yellow	х	х	х	
Relay: 13/14, DC OK	Default	Closed	Closed	Open	х
Signal Out 1: U _{In} <19,2 V	Deiault	Active High	Active High	Active High	Active Low
LED Off LED On - LED Flashing X Not relevant					



14.9 SLEEP MODE signaling

In SLEEP MODE, all LEDs are off, all signals are low, and the relay switching contact is open.

14.10 Special immunity for the signal level

14.10.1 Surge protection for the high-voltage area at the power plant

Surge protection (Phoenix Contact Order No.: 2907925 or comparable protection) must be implemented for power plant applications when using signal connection types t (telecommunications area), h (high voltage area) or f (field) in accordance with IEC/EN 61850-3 or signal connection types 3 (process area) and 4 (high voltage area) in accordance with EN 61000-6-5.

When using the digital signals, a relay (Phoenix Contact Order No.: 2900299 or a comparable relay) can be implemented.

14.10.2 Surge protection for devices in use in safety-related systems

Surge protection (Phoenix Contact Order No.: 2907925 or comparable protection) must be implemented for railway applications when using signals in accordance with EN 61000-6-7 for devices provided to perform functions in safety-related systems (functional safety) in industrial settings.

When using the digital signals, a relay (Phoenix Contact Order No.: 2900299 or a comparable relay) can be implemented.

Figure 39 Schematic diagram, signal wiring with TRABTECH surge protection





Figure 40 Schematic diagram, signal wiring with relay module




15 Operating modes

15.1 Series operation

To double the output voltage, connect two power supplies in series. Only use power supplies with the same performance class and configuration for series operation. If two 24 V DC power supplies are connected in series, an output voltage of 48 V DC is available to supply the loads.


Figure 41 Schematic diagrams in series operation



15.2 Parallel operation

You can connect several power supplies in parallel in order to increase the power or to supply the loads redundantly.

Figure 42 Schematic diagram in parallel operation



Observe the following points when carrying out parallel connection:

- 1. Use power supplies of the same type and performance class
- 2. Setting the same output voltages

QUINT POWER app.

- 3. Using the same cable cross sections for wiring
- 4. Using the same cable lengths for the DC convergence point
- 5. Operating power supplies in the same temperature environment
- 6. When three or more power supplies are connected in parallel, each output must be protected (e.g., with circuit breakers, fuses or decoupling modules)



We recommend the configuration "parallel operation" for a parallel connection. For more detailed information on the operating mode for parallel operation, refer to the user manual for the QUINT POWER software or the

15.2.1 Redundancy operation

Redundant circuits are suitable for supplying systems and system parts which place particularly high demands on operational reliability.

If energy is to be supplied to the load with 1+1 redundancy, two power supplies of the same type and performance class must be used. In the event of an error, it must be ensured that one of the power supplies is able to provide the total required power for the load. This means that in redundancy mode, two 5 A power supplies supply a load with a nominal current of 5 A, for example. During normal operation of the power supplies, each power supply therefore supplies 2.5 A.

Always use cables with the same cross sections and lengths when wiring the power supplies on the DC output side.

Redundancy modules can be used to 100% decouple two power supplies from one another and to ensure the supply. A distinction is made here between passive and active redundancy modules. Optimum decoupling with simultaneous monitoring and minimal power dissipation can be achieved with the QUINT ORING or QUINT S-ORING active redundancy module.

Figure 43 Schematic diagram, redundant operation with QUINT ORING





Figure 44 Schematic diagram, redundant operation with QUINT S-ORING



Certain specifications apply in redundancy operation with regard to the configuration of the keepout areas. In redundancy operation, the power supplies are operated with

109371_en_00

maximum half the nominal power. The keepout areas are therefore reduced.

Using the signaling settings, you can monitor whether both power supplies are being operated with \leq half the nominal load. In the case of system extension, an overload is prevented if one of the power supplies fails.


15.2.2 Increased power

When n power supplies are connected in parallel, the output current is increased to n x I_N . Parallel connection for increased power is used when extending existing systems. If the individual power supply does not cover the current consumption of the most powerful load, parallel connection of power supplies is recommended.



When three or more power supplies are connected in parallel, each output must be protected separately, e.g., by a circuit breaker, fuse or decoupling module such as QUINT ORING, QUINT S-ORING or QUINT DIODE.

Figure 45 Schematic diagram of increased performance




16 Derating

The QUINT POWER power supply runs in nominal operation without any limitations. For operation outside the nominal range, the following points should be observed depending on the type of use.

16.1 Ambient temperature

When operating the power supply at an ambient temperature of > 60 °C, a power derating of 2.5 %/K should be observed. Up to an ambient temperature of 40 °C, the power supply can take power from the static boost for a sustained period. In the 40 °C to 60 °C temperature range, the power supply can output more than the nominal power for a sustained period.




16.2 Input voltage

Derating 5%/V					
U _{In}	U _{In} T _A I		U _{Out}		
< 18 V	≤ 60 °C	۱ _N	24 V DC		
< 18 V	≤ 40 °C	I _{Stat. Boost}	24 V DC		

16.3 Installation height

The power supply can be operated at an installation height of up to 2000 m without any limitations. Different data applies for installation locations above 2000 m due to the differing air pressure and the reduced convection cooling associated with this (see technical data section). The data provided is based on the results of pressure chamber testing performed by an accredited test laboratory.

Figure 47 Output power depending on the installation height



16.4 Position-dependent derating

The fanless convection-cooled power supply can be snapped onto all DIN rails according to EN 60715.





The power supply should be mounted horizontally for heat dissipation reasons (DC connection terminal blocks facing downward). Please observe the derating for any mounting other than the normal mounting position. Reduce the output power based on the prevailing ambient temperature.

The recommended output power for different mounting positions and ambient temperatures can be found in the characteristic curves below.


Exceeding these values will reduce the service life of the power supply.

16.4.1 Normal mounting position







16.4.2 Rotated mounting position 90° Z-axis




16.4.3 Rotated mounting position 180° Z-axis







16.4.4 Rotated mounting position 270° Z-axis





16.4.5 Rotated mounting position 90° X-axis





16.4.6 Rotated mounting position 270° X-axis





>>Phoenix Contact(菲尼克斯)