SAFETY ORGANIZATIONS

THIS FILTER HAS BEEN FORMALLY RECOGNIZED, CERTIFIED OR APPROVED BY THE LISTED AGENCY. THEREFORE, ALL TEST/REQUIREMENTS SPECIFIED IN THE LATEST REVISION OF THE FOLLOWING AGENCY STANDARDS HAVE BEEN MET:

UL RECOGNIZED: UL 1283 CSA CERTIFIED: CSA 22.2, # 8 VDE APPROVED: EN133200

OPERATING SPECIFICATIONS

LINE CURRENT/VOLTAGE: 10 AMP, 120/250 VAC,

10 AMP/40°C, 250 VAC

LINE FREQUENCY: 50-60Hz

MAXIMUM LEAKAGE CURRENT,

COMMON

dΒ

DIFF

dВ

4 7

5 8 12 17 19 18 18

17 22 32 30 30

EACH LINE TO GROUND: µA @120V 60Hz μA @ 250V 50Hz

OPERATING AMBIENT TEMP. RANGE: -10°C TO +40°C @ RATED CURRENT, Ir.

IN AN AMBIENT, $T_{\rm O}$, HIGHER THAN 40°C, THE MAXIMUM OPERATING CURRENT, Io, IS AS FOLLOWS:

 $I_0 = I_r -$

RELIABILITY SPECIFICATIONS

STORAGE TEMPERATURE: -40°C TO +85°C HUMIDITY: 21 DAYS @ 40°C 95% RH. CURRENT OVERLOAD TEST: 6 TIMES In FOR 8 SECONDS

CATALOG # 10EJHS1 EC APPRVD. I DATE 0631-0171-04 12N0V0

TEST SPECIFICATIONS:

INDUCTANCE: 35.0 mH NDMINAL CAPACITANCE: (MEASURED @ 1 kHz, 0.250VAC MAX., $25^{\circ}C\pm1^{\circ}C$)

LINE TO GROUND: μF NONE I THE THITTE: μÆ20% 0.10 DISCHARGE RESISTOR: 1.5M \(\text{\(\alpha\)}

L/G AND L/L I.R.

NO DISCHARGE RESISTOR: 6000M₁ (MIN.) @ 100VDC,

20°C AND 50% RH


RECOMMENDED RECEIVING INSPECTION HIPOT:

LINE TO GROUND: 1500 VAC OR 2250 VDC FOR 1 MINUTE

LINE TO LINE: 1450 VDC FOR I MINUTE

FILTER APPROVAL:

THE BEST WAY TO SELECT AND QUALIFY A FILTER IS FOR YOUR ENGINEERING TO TEST THE UNIT IN YOUR EQUIPMENT.



prior written consent.

MATERIAL & FINISH: AS SUPPLIED

This document is proprietary to CORCOM INC.

and is not to be reproduced nor used for

manufacturing purposes except on CORCOM'S

 CAD FILE:
 G:\CD\10EJHS100
 TYCD # 1-1609008-9

 YCALF:
 __ IDATE:
 CATALOG NO.

PEV

0

10EJHS1

DATE: 11-12-04

ORIG:

ZTN

DRW. BY

单击下面可查看定价,库存,交付和生命周期等信息

>>TE Connectivity(泰科)