SAFETY ORGANIZATIONS

THIS FILTER HAS BEEN FORMALLY RECOGNIZED, CERTIFIED OR APPROYED BY THE LISTED AGENCY. THEREFORE, ALL TEST/REQUIREMENTS SPECIFIED IN THE LATEST REVISION OF THE FOLLOWING AGENCY STANDARDS HAVE BEEN MET:

UL RECOGNIZED: UL 1283 CSA CERTIFIED: CSA 22.2, # 8 YDE APPROYED: EN 133200

OPERATING SPECIFICATIONS

LINE CURRENT/VOLTAGE: 10 AMP/40°C, 120/250VAC

LINE FREQUENCY: 50-60Hz

MAXIMUM LEAKAGE CURRENT,

0.22mA @ 120V, 60Hz EACH LINE TO GROUND: 0.38mA @ 250V, 50Hz

OPERATING AMBIENT TEMP. RANGE: -10°C TO +40°C @ RATED CURRENT, Ic. IN AN AMBIENT, T_0 , HIGHER THAN 40°C, THE MAXIMUM OPERATING CURRENT, I_0 , IS AS FOLLOWS: $I_0 = I_0 - \sqrt{100 - I_0}$ $I_0 = I_r \neg$ 60

RELIABILITY SPECIFICATIONS:

STORAGE TEMPERATURE: -40°C TO +85°C HUMIDITY: 21 DAYS @ 40°C 95% RH. CURRENT DYERLOAD TEST: 6 TIMES In FOR 8 ZECONOS

TEST SPECIFICATIONS:

INDUCTANCE: 0.36mH NOMINAL

INDUCTÁNCE: GROUND CHOKE = 0.275mH NOMINAL CAPACITÁNCE: (MEÁSURED @ 1KHz, 0.250VÁC MÁX., 25°C±1°C)

LINE TO GROUND: 0.0059µF ±20% LINE TO LINE: 0.1015µF ±20% 1.5M DISCHARGE RESISTOR

L/G AND L/L I.R. NO DISCHARGE RESISTOR: 6000Ma (MIN.) @ 100VDC,

20°C AND 50% RH

CATALOG # 10ED1C

ECO # APPRVD DATE

121N0V06


RECOMMENDED RECEIVING INSPECTION HIPOT:

1500YAC DR 2250YDC FOR 1 MINUTE 1450YDC FOR 1 MINUTE LINE TO GROUND:

LINE TO LINE:

FILTER APPROVAL:

THE BEST WAY TO SELECT AND QUALIFY A FILTER IS FOR YOUR ENGINEERING TO TEST THE UNIT IN YOUR EQUIPMENT.



单击下面可查看定价,库存,交付和生命周期等信息

>>TE Connectivity(泰科)