SAFETY ORGANIZATIONS

THIS FILTER HAS BEEN FORMALLY RECOGNIZED, CERTIFIED OR APPROVED BY THE LISTED AGENCY. THEREFORE, ALL TEST/REQUIREMENTS SPECIFIED IN THE LATEST REVISION OF THE FOLLOWING AGENCY STANDARDS HAVE BEEN MET:

UL RECOGNIZED: UL 1283 CSA CERTIFIED: CSA C22.2 No. 8 VDE APPROVED: EN 60939-2

OPERATING SPECIFICATIONS

LINE CURRENT/VOLTAGE: 130 AMP 277 VAC LINE TO GROUND 130 AMP 480 VAC PHASE TO PHASE

LINE FREQUENCY:

50-60Hz

MAXIMUM LEAKAGE CURRENT,

EACH LINE TO GROUND:

30 mA @ 277VAC 50 HZ

OPERATING AMBIENT TEMP. RANGE: ~10°C TO ± 50 °C @ RATED CURRENT, $1_{\rm P}$. IN AN AMBIENT, $1_{\rm Q}$, HIGHER THAN 50°C, THE MAXIMUM OPERATING

CURRENT, ID, IS AS FOLLOWS:

 $I_0 = I_r - \sqrt{\frac{100 - T_0}{50}}$

RELIABILITY SPECIFICATIONS:

STORAGE TEMPERATURE: -40°C TO +85°C HUMIDITY: 21 DAYS # 50°C 95% RH. CURRENT OVERLOAD TEST: 6 TIMES 1r FOR 8 SECONDS

CUSTOMER DRAWING
CATALOG # 130BCF6
ECR# APPRVD DATE
15-011624 TAM 08DEC15

TEST SPECIFICATIONS:

INDUCTANCE: .55 mH NOMINAL

CAPACITANCE: (MEASURED @ 1KHz, 0.250VAC MAX., 25°C±1°C)

LINE TO GROUND: LINE TO LINE: 2.17 μF±20% 6.60 μF±20% 660K


DISCHARGE RESISTOR: NO DISCHARGE RESISTOR:

RECOMMENDED RECEIVING INSPECTION HIPOT:

LINE TO GROUND: 1850 VDC FOR 1 MINUTE LINE TO LINE: 1850 VDC FOR 1 MINUTE

FILTER APPROVAL:

THE BEST WAY TO SELECT AND QUALIFY A FILTER IS FOR YOUR ENGINEERING TO TEST THE UNIT IN YOUR EQUIPMENT.



Downloaded From Oneyac.com

单击下面可查看定价,库存,交付和生命周期等信息

>>TE Connectivity(泰科)